



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001



No: F.6/DFS/MS/School/2025/WZ/ 233

Dated: 17/04/2025

To,

The Principal,  
MCD Primary Co-ed School,  
Wazirpur Industrial Area, C- Block,  
Delhi-110052.

Sub: - Regarding issuance of Fire Safety Certificate in r/o MCD Primary Co-ed School located at Wazirpur Industrial Area, C- Block, Delhi- 110052.

Sir,

This has reference to your e mail id dated 10/03/2025 on the subject cited above. In this connection, it is to inform you that the inspection of above said school building has been carried out by officer concerned of this department on 08.04.2025 to see the to see the compliance of the requisite fire safety measures. Sh. Gagan Kumar (In-charge) was present at the time of inspection.

During the course of inspection it was observed that school building is comprised of Ground and First floor. Your request for issuance of FSC is rejected due to the following shortcomings:-

1. Class rooms having more than 45 students shall have two numbers of exits.
2. Electrical meter and panel installed under the staircases have to be removed to a safer place or been segregated.

You are advised to rectify the above-mentioned shortcomings under intimation to this department.

Yours Faithfully

(Atul Garg)  
Director

Ph. 011-23414000

Copy to:-

1. Director of Education, MCD, Civic Centre, New Delhi.

15/4/2025