

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No.F6/DFS/MS/School/2025/NDZ/ 303

Dated: 30/04/2025

To

The Principal  
M.C.D. Primary School,  
Johripur, Delhi-110094.

**Sub.:- Regarding renewal of Fire Safety Certificate in r/o M.C.D. Primary School,  
Johripur, Delhi-110094.**

Sir,

Please refer to your letter No. Nil out door diary no. 635 dated 16/04/2025 on the subject cited above. In this connection it is to inform you that the school premises was visited by the officer concerned of this department on 24/04/2025 in the presence of Mrs. Sunita (Principal) and observed that the shortcomings issued by this department vide letter No. F6/DFS/MS/School/2015/2263 dated 06/10/2015. (Copy Enclosed) still not complied.

In view of above, the application for issuance of Fire Safety Certificate is rejected. The occupancy of the building / premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner / occupier.

Yours faithfully,

Encl: as above

  
(ATUL GARG)  
DIRECTOR  
DELHI FIRE SERVICE.

Copy to:-

1. The Dy. Director of Education, B-Block, Yamuna Vihar, Delhi-110053.

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE NEW DELHI-110001**

No. f6/dfs/ms/school/2015/2263

Dated: 06/10/15

To,  
The Principal,  
EDMC Primary School, (Shift-II<sup>nd</sup>),  
Johripur, Delhi-110094

**Subject:** - Regarding Fire Safety Certificate.

Madam/Sir,

This is in reference to your letter No.-JP-I/2015 dated-06/08/2015 on the subject cited above. In this connection, it is to inform you that the officer concerned of this department has carried out the inspection of the above-mentioned school from fire safety point of view in presence of Mr. Tejpal Singh (Incharge) on 08/09/2015. During the course of inspection, the following points / shortcomings were noticed in the school building comprising of ground plus one upper floor.

1. An additional fire escape staircase not less than 0.75 meter wide shall be provided.
2. Only 04 fire extinguishers provided in place of 08 fire extinguishers as required.

In view of above, the school building can not be considered for grant of fire safety certificate at this stage. Therefore you are suggested to rectify the above mentioned shortcomings under the intimation to this department for further course of action.

Yours faithfully

  
(Rajesh Panwar)  
Dy. Chief Fire Officer  
Ph.011-23412025

o/c  


Copy to:-

1. The Principal,  
EDMC Primary School (Shift-I<sup>st</sup>),  
Johripur, Delhi-110094
2. The Director of Education, EDMC,  
Udyog Sadan, Plot No.419, FIE,  
Patparganj Industrial Area, Delhi-110092