



No. F6/DFS/MS/School/SZ/2025/ 1366

Dated: 02/12/2025

FIRE SAFETY CERTIFICATE

Certified that the MCD Primary School, Kalkaji Central DD Block, Kalkaji, New Delhi 110019, comprised of Ground plus one upper floor owned/occupied by MCD Delhi was earlier issued Fire Safety Certificate vide letter No F6/DFS/MS/School/2022/SZ/1025 dated 19/09/2022. Now, the school building was re-inspected by officer concerned of this department on 22/11/2025 in presence of Mrs. Sushma Rani (Principal) of the school and found that the said school building have deemed complied with the fire prevention and fire safety requirements in accordance with Directorate of Education circular no. F16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 issued by Directorate of Education, Govt of NCT of Delhi and that the school building is fit for occupancy class Group - B "Educational Building" with effect from 02/12/2025 for a period of three years in accordance with Rule 36 unless renewal under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the DFS Rules, 2010.

Issued on 02/12/2025 at New Delhi by.



(A.K.Malik)

Dy. Chief Fire Officer
Delhi Fire Service

o/c @

Copy to: -

1. The Directorate of Education, MCD, Civic Centre, Minto Road, New Delhi-110019.
2. The Principal, MCD Primary School, Kalkaji Central DD Block, Kalkaji, New Delhi 110019.

Conditions for the validity of Fire Safety Certificate

1. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry
2. All the means of escape shall be kept free of all the type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipment's and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the firefighting equipment's shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
5. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc. may be got verified from the authorities concerned.
6. This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.

2/14
INSPECTION REPORT

01.	Name & address of the building	MCD Primary School, Kalkaji Central DD Block, Kalkaji, New Delhi 110019.		
02.	Building is comprised of	Ground plus one upper floor		
03.	Type of occupancy	Educational Building, Group - B (School)		
04.	Type of case	Renewal Case		
05.	Details of previous FSC	F6/DFS/MS/School/2022/SZ/1025 dated 19/09/2022		
06.	Fire safety directives letter no.	F16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011		
07.	Date of inspection	22/11/2025		
08.	Name of the inspecting officers	Yashwant Singh Meena, ADO/BCP		
09.	Name of the designation of officer from the building side	Mrs. Sushma Rani (Principal)		
10.	Year of construction	2010		
11.	Applicant's letter no.	Outdoor dairy no. 7957 dated 07/11/2025		
S.No	Minimum standard of fire prevention and fire safety U/R 33	As per old NOC	Provided at site	Remarks MR/NMR
01.	Access to Building:			
	A Road width	Accessible	Provided	MR
	B Gate width	4.0 meter	4.0 meter	MR
	C Width of internal road	N/A	N/A	N/A
02.	Number, Width, Type and Arrangement of Exits:			
	A Number of staircases			
	a Upper floor	02 nos.	Provided 02 Nos	MR
	C Basement	N/A	N/A	N/A
	B Width of staircases			
	a Upper floor	1.50 m	1.50 m each	MR
	C Basement	N/A	N/A	N/A
	C Protection of exits			
	a Fire check door	N/A	N/A	N/A
	b Pressurization	N/A	N/A	N/A
	D No. of continuous staircases to terrace	01 No	Provided	MR
	E Width of corridor	1.50 meter	Provided	MR
	F Door size	1 meter	Provided	MR
03.	Compartmentation:			
	A Fire check door	N/A	N/A	N/A
	B Sealing of electrical shafts	N/A	N/A	N/A
	C Fire rating of shaft door	N/A	N/A	N/A
	D Water curtain	N/A	N/A	N/A
	E Fire dampers	N/A	N/A	N/A
04.	Smoke Management System:			
	A Basement	N/A	N/A	N/A
	B Upper floor	N/A	N/A	N/A
05.	Fire Extinguisher:			
	A Total numbers	10 No's	Provided	MR
	B Types	ABC	ABC/CO ₂ type	MR
	C ISI marking	ISI Marked	Provided	MR

(3)


06. First-Aid-Hose Reel:					
	A	Total numbers of each floor	N/A	N/A	N/A
	B	Length of hose reel hose	N/A	N/A	N/A
	C	Nozzle diameter	N/A	N/A	N/A
07. Automatic Fire Detection and Alarming System:					
	A	Type of detectors	N/A	N/A	N/A
	B	Location of main panel	N/A	N/A	N/A
	C	Location of repeater panel	N/A	N/A	N/A
	D	Alternate source of power	N/A	N/A	N/A
	E	Hooters	N/A	N/A	N/A
08. MOEFA:			N/A	N/A	N/A
09. Public Address System:			N/A	N/A	N/A
10. Automatic Sprinkler System:					
	A	Basement	N/A	N/A	N/A
	B	Upper floor	N/A	N/A	N/A
	C	Sprinkler above false ceiling	N/A	N/A	N/A
11. Internal Hydrants:					
	A	Size of riser/down-comer	N/A	N/A	N/A
	B	Number of hydrants per floor	N/A	N/A	N/A
	C	Hose box	N/A	N/A	N/A
12. Yard Hydrants:					
	A	Total number of hydrants	N/A	N/A	N/A
	B	Hose box	N/A	N/A	N/A
13. Pumping Arrangements:					
1 Ground level					
	A	Discharge of main pump	N/A	N/A	N/A
	B	Head of main pump	N/A	N/A	N/A
	C	Number of main pumps	N/A	N/A	N/A
	D	Jockey pump out put	N/A	N/A	N/A
	E	Jockey pump head	N/A	N/A	N/A
	F	Standby pump out put	N/A	N/A	N/A
	G	Standby pump head	N/A	N/A	N/A
	H	Auto starting /manual stopping	N/A	N/A	N/A
	I	Pump house access	N/A	N/A	N/A
2 Terrace Level					
	A	Discharge of pump	N/A	N/A	N/A
	B	Head of the pump	N/A	N/A	N/A
	C	Power supply	N/A	N/A	N/A
	D	Auto starting of pump	N/A	N/A	N/A
14. Captive Water Storage for Fire Fighting:					
	A	Underground tank capacity	N/A	N/A	N/A
	B	Draw-off connection	N/A	N/A	N/A
	C	Fire service inlet	N/A	N/A	N/A
	D	Access to tank	N/A	N/A	N/A
	E	Overhead tank capacity	N/A	N/A	N/A

u

15.	Exit Signage:	Required	Provided	MR
16.	Provision of Lifts:			
	A Pressurization of lift shaft	N/A	N/A	N/A
	B Pressurization of lift lobby	N/A	N/A	N/A
	C Communication in lift car	N/A	N/A	N/A
	D Firemen's grounding switch	N/A	N/A	N/A
	E Lift signage	N/A	N/A	N/A
17.	Standby Power Supply:	N/A	N/A	N/A
18.	Refuge Area:			
	A Total area	N/A	N/A	N/A
	B Location	N/A	N/A	N/A
19.	Fire Control Room:			
	A Detector system panel	N/A	N/A	N/A
	B Flow switch panel	N/A	N/A	N/A
	C PA system panel	N/A	N/A	N/A
	D Battery backup	N/A	N/A	N/A
	E Building floor plans	N/A	N/A	N/A
20.	Special Fire Protection systems for protection of special Risks, if any:	NA	N/A	N/A

The fire protection system was randomly checked and tested and was found functional at the time of inspection.

Keeping in view of the deemed compliance of minimum standards on fire prevention and fire safety measures as required under the Rules the Fire Safety Certificate issued vide letter no F6/DFS/MS/School/2022/SZ/1025 dated 19/09/2022, under the rule 37 of the Delhi Fire Service Rules, 2010 is **recommended**.


24/11/2025



Signature of the Inspecting Officer
Name: - Yashwant Singh Meena
Designation: - ADO/BCP

DO/SD


26/11/25
Ravinder Singh




27/11/25
A. K. MALIK
Principal Director

By. CFO to 

27/11/25

Dy. CFO (ex)


28/11/25
A.K. MALIK
Principal Director

ADO/BCP