

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI-110001

C-12

No. F6/DFS/MS/School/2025/NDZ/284
To,

Dated: 25/04/2025

The principal,
MCD Primary School,
M-Block, Sunder Nagri,
New Delhi-110093.

Subject: Inspection report of MCD Primary School, M-Block, Sunder Nagri, New Delhi-110093, from Fire Safety and means of escape point of view.

Sir,

Please refer to your Email dated 16/04/2025 on the subject cited above. In this connection, it is to inform you that, the site was visited by the officer concerned of this department in presence of Mr. K.P. Singh (Principal) of the school on dated 22/04/2025 and observed that the shortcomings issued by this department vide letter No. F6/DFS/MS/School/2022/NDZ/206 dt. 04/05/2022 & F6/DFS/MS/School/2018/2380 dt. 30/05/2018 (copy enclosed) have still not complied.

In view of above, the application for issuance of Fire Safety Certificate is rejected. The occupancy of the building / premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner / occupier.

Yours Faithfully,

Encl: as above


(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

dca 42

Copy to:-

The Director of Education, MCD Civic Centre, Jawahar Lal Nehru Marg, New Delhi-110002.

C-9

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE NEW DELHI-110001**

No. F6/DFS/MS/School/2022/NDZI/206

Dated: 04/05/2022

To,

The Manager
EDMC Primary School,
M-Block, Sunder Nagri,
Delhi-110093.

Subject: -Regarding issuance of Fire Safety Certificate in r/o EDMC Primary School M-Block Sunder Nagri Delhi-110093

Sir,

Please refer to letter. Nil dated 05/04/2022 on the subject cited above. In this regard, it is to inform you that, the inspection of the above said premises was carried out by the officer concerned of this department in presence of Mr. Anil (Teacher) of the school on dated 25/04/2022. During the inspection it was observed that the shortcomings as communicated earlier vide letter No. F6/DFS/MS/2018/2380 dated 30/05/18 are yet to be rectified. Copy of the same is enclosed for your ready reference.

Yours faithfully


21/5/22

(Dr. S.K Tomar)
Dy.Chief Fire Officer



Copy to:-

- 1) The Director of Education,
Udyog Sadan, Plot No.419, FIE,
Patparganj Industrial Area, Delhi-110092

C-4

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001**

No. F6/DFFS/MS/2018/2380

Dated 30/5/18

To,
The Principal,
EDMC Primary School,
M- Block, Sunder Nagri,
Delhi 110093

Sub:- Regarding Issuance Fire Safety Certificate.

Sir,

This is in reference to your letter No. nil dated 16/03/2018 on the subject cited above. In this connection, it is to inform you that the officer concerned of this department has carried out the inspection of the above mentioned EDMC Primary School from fire safety point of view in presence of Mr. Jitender Kumar, Attendant of the School. During the course of inspection it was observed that the following points / shortcomings were noticed in the building comprised of ground plus two upper floors.

1. Only 03 fire extinguisher provided in place of 06 fire extinguishers as required.
2. First-Aid hose reels (01 nos.) not provided at each floor as required.
3. A fire pump having 450 LPM output at 40 meters head not provided.
4. Exit Signage were not provided.

In view of above, the building can not be considered for issue of Fire Safety Certificate at this stage. Therefore you are suggested to rectify the above mentioned shortcomings under the intimation to this department for further course of action.

Yours faithfully


(Vipin Kental)
Chief Fire Officer

Copy to:-

The Director of Education, EDMC
Udyog Sadan, Plot No. 419, FIE,
Patparganj, Delhi 92

O/C
