



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

75
आजादी का
अमृत महोत्सव

No. F6/DFS/MS/EH/NDZ/2026/ 03

Dated: 05/01/2026

To,

The Commissioner,
Municipal Corporation of Delhi,
Civic Centre, Minto Road,
New Delhi

Sub: Regarding renewal of FSC in r/o McDonalds Family Restaurant (A unit of Connaught Plaza Restaurants Pvt. Ltd), 5/76, West Ajmal Khan, Padam Singh Marg, Karol Bagh, New Delhi - 110005.


Sir,

Please refer to online application No. 2025121715826 dated 18/12/2025, on the subject cited above. In this connection, it is to inform you that the said restaurant was inspected by the officer concerned of this department on 26/12/2025 in the presence of Ms. Rachna (Restaurant Manager) and following shortcomings were observed: -

1. Alternate staircase was found removed.
2. Width of main exit door is 1.10 mtr. against the requirement of 1.50 mtr.

Keeping in view of the above shortcomings, the application for renewal of Fire Safety Certificate cannot be considered at this stage and stands rejected. Further, the occupancy of the building premises in the absence of requisite fire safety measures shall be at the risk and liability of the owner/occupier.

Yours faithfully,


21/12/26
(A. K. Malik)
Dy. Chief Fire Officer
Delhi Fire Service

o/c BR

Copy to: -

1. The Manager, McDonalds Family Restaurant (A unit of Connaught Plaza Restaurants Pvt. Ltd), 5/76, West Ajmal Khan, Padam Singh Marg, Karol Bagh, New Delhi - 110005.