



Dated: 24/03/2026

F6/DFS/MS/EH/SZ/2026/ 241

FIRE SAFETY CERTIFICATE

Certified that the M/s **Mehak Restaurant** located at F - 39, Ground floor, East of Kailash, New Delhi - 110065 in a building comprised of Small Basement (Storage), Ground plus two upper floors, owned/occupied by **Mehak Restaurant** was earlier Fire Safety Certificate issued from this department vide letter No. F6/DFS/MS/EH/2022/SZ/194 dated 05/07/2022. The said premises was re-inspected by the officer concerned of this department on 11/03/2026 in presence of Mr. Rupesh (Manager) and found that the fire premises / building have deemed complied with the prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule 2010 and that the premises / building is fit for occupancy class Group D "Assembly Building" (Restaurant running on Ground floor only) with effect from 24/03/2026 for a period of **three years** in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rule 2010, printed below.

Issued on 24/03/2026 at New Delhi by.


23/3/26
A. K Mailk
Dy. Chief Fire Officer
Delhi Fire Service
0/1/10

Copy to: -

1. The Dy. Health Officer, Public Health Department, South Zone, Green Park, Delhi - 110016 (Ref. MHA Application No. 2026022502072 dated 26/02/2026)
2. The Owner, Mehak Restaurant located at F - 39, Ground floor, East of Kailash, New Delhi - 110065.

Condition for the validity of fire safety certificate

1. All the means of escape shall be kept free of all the type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipment's and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the firefighting equipment's shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc. may be got verified from the authorities concerned.
5. Basement shall be used as per NBC/UBBL.
6. This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
7. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
8. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1	Name & Address of the building	M/s Mehak Restaurant located at F - 39, Ground floor, East of Kailash, New Delhi - 110065.		
2	Building is comprised of	Small Basement (Storage), Ground plus two upper floors Restaurant running on Ground floor only.		
3	Type of occupancy	Group - D Assembly Building (Eating House)		
4	Type of case	Renewal Case		
5	Details of previous FSC	F6/DFS/MS/EH/2022/SZ/194 dated 05/07/2022		
6	Fire safety direction letter no.	F6/DFS/MS/EH/2005/718 dated 04/04/2005		
7	Date of inspection	11/03/2026		
8	Name of the inspecting officers	Yashwant Singh Meena, ADO/M. Road		
9	Name of the designation of officer From the building side	Mr. Rupesh (Manager)		
10	Year of construction	2003		
11	Applicant's letter no.	MCD Application No. 2026022502072 dated 26/02/2026		
S. No	Minimum standard of Fire Prevention and Fire Safety U/R 33	As per Old FSC Requirements	Provide at site	Remarks MR/NMR
1	Access to Building			
	A Road width	Required	12 metres.	MR
	B Gate width	N/A	N/A	N/A
	C Width of internal roads	N/A	N/A	N/A
2	Number, Width, Type & Arrangement of Exits			
	A No. of staircase:	Restaurant at ground floor only		
	a) Upper floor	N/A	N/A	N/A
	b) Basements	N/A	N/A	N/A
	B Width of the staircase:			
	a) Upper floors	N/A	N/A	N/A
	b) Basements	N/A	N/A	N/A
	C Protection of Exits			
	a) Fire check door	N/A	N/A	N/A
	b) Pressurization	N/A	N/A	N/A
	D No. of continuous staircase to terrace:	N/A	N/A	N/A
	E Width of the corridor	N/A	N/A	N/A
	F Door size	02 exit	1.16 m & 0.75 m	MR
3	Compartmentation:			
	A Fire check doors	N/A	N/A	N/A
	B Sealing of horizontal & vertical opening	N/A	N/A	N/A
	C Fire rating of shaft doors	N/A	N/A	N/A
	D Water curtain	N/A	N/A	N/A
	E Fire dampers	N/A	N/A	N/A
4	Smoke management System:			
	A Basements	N/A	N/A	N/A
	B Upper floors	Required	Provided	MR
5	Fire Extinguishers			
	A Total numbers	04 nos.	06 nos.	MR
	B Types	ABC & CO2	ABC & CO2	MR
	C ISI marking	Required	Provided	MR


6	First Aid Hose Reel				
	A	Total no. at each floor	01 no.	01 no.	MR
	B	Length of hose reel	30 m	30 m	MR
	C	Nozzle diameter	05 mm	05 mm	MR
7	Automatic Fire Detection and Alarm System				
	A	Type of detectors	N/A	N/A	N/A
	B	Location of main Panel	N/A	N/A	N/A
	C	Location of repeater panel	N/A	N/A	N/A
	D	Alternate power source	N/A	N/A	N/A
	E	Hooter's location	N/A	N/A	N/A
8	MOEFA		Required	Provided	MR
9	Public Address System		Required	Provided	MR
10	Automatic Sprinkler System				
	A	Basement	N/A	N/A	N/A
	B	Upper floor	N/A	N/A	N/A
	C	Sprinklers above false ceiling	N/A	N/A	N/A
11	Internal Hydrants				
	A	Size of the riser/down comer	100 mm	Provided	MR
	B	No. of hydrants per floor	01 no.	Provided	MR
	C	Hose box	01 no.	Provided	MR
12	Yard Hydrants				
	A	Total no. of hydrants	N/A	N/A	N/A
	B	Hose box	N/A	N/A	N/A
13	Pumping arrangements				
	A	Ground Level			
		a) Discharge of main pump	N/A	N/A	N/A
		b) Head of Main Pump	N/A	N/A	N/A
		c) Number of Main Pump	N/A	N/A	N/A
		d) Jockey Pump out put	N/A	N/A	N/A
		e) Jockey Pump Head	N/A	N/A	N/A
		f) Standby Pump out put	N/A	N/A	N/A
		g) Standby Pump Head	N/A	N/A	N/A
		h) Auto Starting/ Manual stopping	N/A	N/A	N/A
	B	Terrace Level			
		Discharge of Pump	225 LPM	Provided	MR
		Head of terrace pump	38 m	Provided	MR
		Power supply	Required	Provided	MR
		Auto starting of pump	Required	Provided	MR
14	Captive Water Storage for Fire Fighting.				
	A	Underground tank capacity	N/A	N/A	N/A
	B	Draw off connection	N/A	N/A	N/A
	C	Fire Service Inlet	N/A	N/A	N/A
	E	Access to tank	N/A	N/A	N/A
	D	Overhead tank capacity	2500 litres	Provided	MR
15	Exit Signage		Required	Provided	MR
16	Provision of lift				
	A	Pressurization of lift shaft	N/A	N/A	N/A
	B	Pressurization of lift lobby	N/A	N/A	N/A
	C	Communication in lift car	N/A	N/A	N/A
	D	Fireman switch	N/A	N/A	N/A
	E	Lift signage	N/A	N/A	N/A
17	Standby Power Supply		Required	Provided	MR

18	Refuge Area			
A	location	N/A	N/A	N/A
B	Total area	N/A	N/A	N/A
19	Fire Control Room			
A	Fire Detection System panel	N/A	N/A	N/A
B	Flow switch panel	N/A	N/A	N/A
C	P A system panel	N/A	N/A	N/A
D	Battery backup	N/A	N/A	N/A
E	Building floor plan	N/A	N/A	N/A
20	Special Fire Protection for special risk if any			
A	Special Fire Protection system for Protection of Special Risk, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested, checked at random and found functional at the time of inspections. The earlier shortcomings issued vide letter no. F6/DFS/MS/EH/SZ/2026/168 dated 24/02/2026 by this department has been rectified by the management.

Keeping in view of the substantial compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, the FSC issued vide letter No. F6/DFS/MS/EH/2022/SZ/194 dated 05/07/2022 renewal under the Rules 37 of Delhi Fire Service Rules 2010 is recommended.

- Last disposal date of the case is 27.03.2026


 Signature of the Inspecting Officer
 Name: Yashwant Singh Meena
 Designation: ADO/Mathura Road

D.O/SD

 16/3/26

Dy. Insp.


Principal Director

 18/3/26
A.K. MALIK

my. CFO to Person.

 19/03/26

my. CFO (SA)


A.K. MALIK

 19/3/26
A.K. MALIK

DO/SD

 19/3/26

P.T.O
