




No. F6/DFS/MS/EH/SZ/2026/ 203

Dated: 11/03/2026

FIRE SAFETY CERTIFICATE

Certified that the M/s **MIDO** (Flying Sparrow Hospitality Private Limited) located at HS1, Second floor, Kailash Colony Market, New Delhi – 110048 in a building comprised of basements, ground plus two upper floors, owned/occupied by Flying Sparrow Hospitality Private Limited was earlier issued Fire Safety Certificate vide letter No. F6/DFS/MS/EH/SZ/2022/226 dated 08/08/2022 (in the name of M/s 3 Idiots restaurant). The premises was re-inspected by the officer concerned of this department on 27/02/2026 in presence of Mr. Sandeep Yadav (Manager) and found that the said premises have deemed complied with the fire prevention and fire safety requirements in the accordance with rule 33 of Delhi Fire Service Rules, 2010 and that the building is fit for occupancy class **Group - D "Assembly Building"** (Restaurant running at Second floor only) with effect from 11/03/2026 for a period of **three years** in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rule 2010, printed below.

Issued on 11/03/2026 at New Delhi by.


10/3/26
(A. K. Malik)
Dy. Chief Fire Officer
Delhi Fire Service
a/c @

Copy to: -

1. The Dy. Health Officer, Public Health Department, South Zone, Green Park, Delhi - 110016. Online application ID No. 2026021101495 dated 12/02/2026 : to kindly ensure the occupancy at detailed above.
2. The Manager, **MIDO** (Flying Sparrow Hospitality Private Limited) located at HS1, Second floor, Kailash Colony Market, New Delhi – 110048.

Conditions for the validity of Fire Safety Certificate

1. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry
2. All the means of escape shall be kept free of all the type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipment's and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the firefighting equipment's shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
5. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc. may be got verified from the authorities concerned.
6. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
7. This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
8. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.
9. This Fire Safety Certificate is valid only for second floor.

INSPECTION REPORT

1	Name & address of the building	M/s MIDO (Flying Sparrow Hospitality Private Limited) located at HS1, Second floor, Kailash Colony Market, New Delhi – 110048.		
2	Building is comprised of	Basement, Ground floor plus two upper floors (Restaurant running on Second floor only)		
3	Type of occupancy	Assembly "Group - D" (Restaurant)		
4	Type of case	Renewal Case		
5	Details of previous FSC	F6/DFS/MS/EH/SZ/2022/226 dated 08/08/2022 (in the name of 3 Idiotss restaurant)		
6	Fire safety directives letter no.	Nil		
7	Date of inspection	27.02.2026		
8	Name of the inspecting officers	Yashwant Singh Meena, ADO/ M. Road		
9	Name of the designation of officer from the building side	Mr. Sandeep Yadav (Manager)		
10	Year of construction	1992	Restaurant running on Second floor only	
11	Applicant's letter no.	Application No. 2026021101495 dated 12/02/2026		
S.No	Minimum standard of fire prevention and fire safety U/R 33	Old NOC Requirement	Provided at site	Remarks MR/NMR
1	Access to Building:			
A	Road width	9.0 meters	Provided	MR
B	Gate width	N/A	N/A	N/A
C	Width of internal road	N/A	N/A	N/A
2	Number, Width, Type and Arrangement of Exits:			
A	Number of staircases			
a	Upper floor	02 nos.	Provided	MR
c	Basement	N/A	N/A	N/A
B	Width of staircases			
a	Upper floor	1.25 m / 0.75 m	1.50 m & 0.85 m	MR
b	Basement	N/A	N/A	N/A
C	Protection of exits			
a	Fire check door	N/A	N/A	N/A
b	Pressurization	N/A	N/A	N/A
D	No. of continuous staircases to terrace	N/A	N/A	N/A
E	Width of corridor	N/A	N/A	N/A
F	Door size	2.0 m & 1.0 m	2.0 m & 1.05 m	MR
3	Compartmentation:			
A	Fire check door	N/A	N/A	N/A
B	Sealing of electrical shafts	N/A	N/A	N/A
C	Fire rating of shaft door	N/A	N/A	N/A
D	Water curtain	N/A	N/A	N/A
E	Fire dampers	N/A	N/A	N/A
4	Smoke Management System:			
A	Basement	N/A	N/A	N/A
B	Upper floor	Required	Exhaust fan	MR

5. Fire Extinguisher: 1/29				
A	Total numbers	06 nos.	08 nos.	MR
B	Types	CO ₂ & ABC	CO ₂ & ABC	MR
C	ISI marking	ISI Marked	Provided	MR
6. First-Aid-Hose Reel:				
A	Total numbers of each floor	01 no	Provided	MR
B	Length of hose reel hose	30 m	Provided	MR
C	Nozzle diameter	05 mm	Provided	MR
7. Automatic Fire Detection and Alarming System:				
A	Type of detectors	N/A	N/A	N/A
B	Location of main panel	N/A	N/A	N/A
C	Location of repeater panel	N/A	N/A	N/A
D	Alternate source of power	N/A	N/A	N/A
E	Hooters	N/A	N/A	N/A
8	MOEFA:	Required	Provided	MR
9	Public Address System:	N/A	N/A	N/A
10. Automatic Sprinkler System:				
A	Basement	N/A	N/A	N/A
B	Upper floor	N/A	N/A	N/A
C	Sprinkler above false ceiling	N/A	N/A	N/A
11. Internal Hydrants:				
A	Size of riser/down-comer	100 mm	Provided	MR
B	Number of hydrants per Branch	01 no.	Provided	MR
C	Hose box	01 no.	Provided	MR
12. Yard Hydrants:				
A	Total number of hydrants	N/A	N/A	N/A
B	Hose box	N/A	N/A	N/A
13. Pumping Arrangements:				
1	Ground level			
A	Discharge of main pump	N/A	N/A	N/A
B	Head of main pump	N/A	N/A	N/A
C	Number of main pumps	N/A	N/A	N/A
D	Jockey pump out put	N/A	N/A	N/A
E	Jockey pump head	N/A	N/A	N/A
F	Standby pump out put	N/A	N/A	N/A
G	Standby pump head	N/A	N/A	N/A
H	Auto starting /manual stopping	N/A	N/A	N/A
2	Terrace Level			
A	Discharge of pump	450 LPM	450 LPM	MR
B	Head of the pump	40 m	40 m	MR
C	Power supply	Required	Provided	MR
D	Auto starting of pump	Required	Provided	MR


14 Captive Water Storage for Fire Fighting: 7/30				
A	Underground tank capacity	N/A	N/A	N/A
B	Draw-off connection	N/A	N/A	N/A
C	Fire service inlet	N/A	N/A	N/A
D	Access to tank	N/A	N/A	N/A
E	Overhead tank capacity	10,000 liters	Provided	MR
15 Exit Signage:		Required	Provided	MR
16 Provision of Lifts:				
A	Pressurization of lift shaft	N/A	N/A	N/A
B	Pressurization of lift lobby	N/A	N/A	N/A
C	Communication in lift car	N/A	N/A	N/A
D	Firemen's grounding switch	N/A	N/A	N/A
E	Lift signage	N/A	N/A	N/A
17 Standby Power Supply:		Required	Provided	MR
18 Refuge Area:				
A	Total area	N/A	N/A	N/A
B	Location	N/A	N/A	N/A
19 Fire Control Room:				
A	Detector system panel	N/A	N/A	N/A
B	Flow switch panel	N/A	N/A	N/A
C	PA system panel	N/A	N/A	N/A
D	Battery backup	N/A	N/A	N/A
E	Building floor plans	N/A	N/A	N/A
20 Special Fire Protection systems for protection of special Risks, if				N/A

Note: - Previous restaurant was running name of 3 Idiots at same address now owner and name of restaurant have been changed.

The fire protection system was randomly checked and tested and was found functional at the time of inspection.

Keeping in view the compliance of the minimum standards of fire prevention and fire safety measures as required under the rules. The Fire Safety Certificate issued vide letter no. F6/DFS/MS/EH/SZ/2022/226 dated 08/08/2022 renewal under rule 37 of the Delhi Fire Service rules 2010 is recommended.

Last disposal date of the case is 12.03.2026



3/3/2026

Signature of the Inspecting Office:
Name: Yashwant Singh Meena
Designation: ADO /Mathura Roac

D.O/SD


5/3/24


A.K. MALIK
Principal Director

My. CF (S) 
06/03/24


A.R. MALIK