

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

C/28

No. F6/DFS/MS/School/WZ/2025/ 547

Dated: 24/04/2025

FIRE SAFETY CERTIFICATE

Certified that the M.M. Public School, located at Vasudha Enclave, Pitampura, Delhi-110034, comprised of Basement + Ground + 03 Upper Floors, owned/occupier by M.M. Public School, was issued FSC vide letter No F6/DFS/MS/School/WZ/2022/366 dated 04/04/2022. The premises was re - inspected by the officer concerned by this department on 29/03/2025 in the presence of Sh. S. R. Pathak and observed that all the fire prevention & fire safety arrangements provided in the premises found in good working condition. The building/premises have deemed complied with fire prevention and fire safety requirements in accordance with DOE Circular No.262-362 dated 17/01/2005 and the building/ premises is fit for occupancy class "Educational" (Group -B) with effect from 24/04/2025 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010. Condition mentioned below.

Issued on 24/04/2025 at New Delhi.

(Atul Garg)
Director

Copy to:

1. Director of Education, GNCT of NCT of Delhi, Old Secretariat, Delhi 110054.
2. The Principal, M.M. Public School, located at Vasudha Enclave, Pitampura, Delhi-110034. Email ID- laurelhigh2@gmail.com.

Conditions for the validity of FSC:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. All the means of escapes/exits shall not be locked/blocked at any time for safe evacuation of the occupants in case of emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
9. The basement shall be used as per BBL.

INSPECTION REPORT

1.	Name & address of the building	M.M. Public School, located at Vasudha Enclave, Pitampura, Delhi-110034.
2.	Type of Occupancy	Educational
3.	Type of Case	Renewal
4.	Details of previous NOC	F6/DFS/MS/School/WZ/2022/366 dated 04/04/2022.
5.	Fire Safety directives letter No	DOE Circular No.262-362 dated 17/01/2005
6.	Date of inspection	29/03/2025
7.	Name of the Inspecting Officers	Sarabjeet Singh ADO (MN)
8.	Name and designation of officers from the building side	Sh. S. R. Pathak
9.	Year of Construction	Before 2009(As per previous inspection report dtd 24/03/2022)
10.	Applicant's letter No.	Email dated 18/02/2025.

The said school building is comprised of Basement + Ground + 03 Upper Floors.

S. No	Minimum Standards on fire prevention and fire safety U/R 33	As per Rule 35 (6) DFS Rule 2010	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	09 mts	Provided	MR
	• Gate width	05 mts	Provided	MR
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	02	Provided	MR
	• Basements	02	Provided	MR
	b. Width of staircases			
	• Upper Floors	1.50 mts each	Provided	MR
	• Basements	1.50 mts each	Provided	MR
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	01	Provided	MR
	e. Width of Corridor	1.5 mts	Provided	MR
	f. Door Size	1.0 mts	Provided	MR
3	Compartmentation.			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke Management System.			
	• Basements	Required	Exhaust Fan Provided	MR
	• Upper floors	NA	NA	NA
5	Fire Extinguishers			
	• Total numbers	36 nos.	Provided	MR
	• Types	CO ₂ , ABC type	Provided	MR
	• IS marking	ISI marked	Provided	MR
6	First-Aid Hose Reels.			
	• Total numbers on each floor	01	Provided	MR
	• Length of hose reel hose	30 mts	Provided	MR
	• Nozzle diameter	05 mm	Provided	MR

		Not Required	
7	Automatic fire detection and alarming system.	NA	NA
	• Type of detectors	NA	NA
	• Location of Main Panel	NA	NA
	• Location of Repeater Panel	NA	NA
	• Alternate source of power	NA	NA
	• Hooters' Location	NA	NA
8	MOEFA	Required	Provided
9	Public Address System.		
10	Automatic Sprinkler System.	Required	Provided
	• Basement	NA	NA
	• Upper Floor	NA	NA
	• Sprinkler above false ceiling	NA	NA
11	Internal Hydrants	100 mm	Provided
	• Size of riser/down-comer	01	Provided
	• Number of hydrants per floor	01	Provided
	• Hose Box		
12	Yard Hydrants.	NA	NA
	• Total number of hydrants	NA	NA
	• Hose Box		
13	Pumping Arrangements.		
	• Ground Level	NA	NA
	➤ Discharge of main Pump	NA	NA
	➤ Head of Main pump	NA	NA
	➤ Number of main pumps	NA	NA
	➤ Jockey Pump out put	NA	NA
	➤ Jockey pump head	NA	NA
	➤ Standby Pump out put	NA	NA
	➤ Standby Pump Head	NA	NA
	➤ Auto Starting/ Manual stopping	NA	NA
	➤ Pump House Access	NA	NA
	• Terrace level	900 LPM	Provided
	➤ Discharge of pump	40 mts	Provided
	➤ Head of the pump	Required	Provided
	➤ Power Supply	Required	Provided
	➤ Auto Starting of pump		
14	Captive Water Storage for fire fighting.		
	• Underground tank capacity	NA	NA
	➤ Draw-off connection	NA	NA
	➤ Fire service inlet	NA	NA
	➤ Access to tank	NA	NA
	• Overhead Tank capacity	10,000 lts	Provided
15	Exit Signage.	Required	Provided
16	Provision of Lifts.		
	• Pressurization of Lift Shaft	NA	NA
	• Pressurization of Lift lobby	NA	NA
	• Communication In lift Car	NA	NA
	• Fireman's Grounding Switch	NA	NA
	• Lift Signage	NA	NA

17	Standby power supply	NA	NA	NA
18	Refuge Area.			
	➤ Total Area			
	➤ Location	NA	NA	NA
19	Fire Control Room	NA	NA	NA
	• Detector System Panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Battery backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any:	NA	NA	NA

The fire protection systems provided in the building were checked and found functional at the time of inspection.

Keeping in view of the deemed compliance of minimum standards of fire prevention and fire safety measures as required under the rules, the NOC vide letter no F6/DFS/MS/School/WZ/2022/366 dated 04/04/2022, renewal under DOE Circular No.262-362 dated 17/01/2005 is recommended.

Q4 (no 1/2)

7/01/04/2025

Signature of the Inspecting Officer
Sarabjeet Singh ADO (MN)

3/4

3/4
3/4/2025

Director

ADP/MN

Sir, F. T is put up for your kind perusal & Signature pls. 1

3/4/2025

Director
ADP

634 MN
3/4/2025

34/ADO/MN
01/04/2025