



No. F6/DFS/MS/GH/NDZ/2026/ 212

Dated: 12/03/2026

FIRE SAFETY CERTIFICATE (FSC)

Certified that the M/s Mona International Hotel located at Property no. 196, Patparganj Road, Madhuban, Delhi-92, building comprised of Basement + Stilt +Upper Ground + 3 upper floors:- Basement - Store, Stilt - Parking, Upper Ground floor to 3rd floor - 09 guest rooms each floors, was granted Fire Safety Certificate (FSC) by this department vide letter no. F6/DFS/MS/GH/NDZ/2023/204 dated 27.12.2023. The premises was re-inspected by officer concerned of this department on 25.02.2026 in presence of Mr. Awdhesh, Maintenance Supervisor and found that the Guest House has complied with the fire prevention and fire safety requirements in accordance with Rule 33 of Delhi Fire Service Rules, 2010. Accordingly, the building/premises is fit for occupancy of Group 'A (Residential) sub division A-1, total 36 guest rooms (Upper Ground floor to 3rd floor - 09 guest rooms each floors,) with effect from 12.03.2026 and valid upto 31.03.2029 in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to conditions under Rule 38 of Delhi Fire service Rules, 2010 printed below.

Issued on 12/03/2026 at New Delhi by


(Dr. S. K. Tomar)

Dy. Chief Fire Officer (NDZ)



Reference: elt.mcdonline application no. 2026021401605.

Conditions for the validity of Fire Safety Certificate

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in.
7. The means of escape shall be kept unobstructed/unlocked for unhindered evacuation in case of an emergency.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub Rule (I) of Rule 37] along with a copy of this Certificate, six month prior to its expiry. Any change in the occupancy shall be intimated to this Deptt. and approval shall be obtained thereto before occupancy of the same.

2/4

INSPECTION REPORT

1	Name & address of the building	M/s Mona International Hotel located at Property no. 196, Patparganj Road, Madhuban, Delhi-92.			
2	Building is comprised of	Basement + Stilt + Upper Ground + 3 upper floors Basement - Store Stilt - Parking Upper Ground floor - 09 guest rooms 1 st floor- 09 guest rooms, 2 nd floor- 09 guest rooms 3 rd floor - 09 guest rooms			
3	Type of occupancy	Residential & Lodging, Group- A			
4	Type of case	Renewal			
5	Details of previous FSC	F6/DFS/MS/GH/NDZ/2023/204 dated 27.12.2023			
6	Fire safety directive letter no.	UBBL/NBC Part-IV 2016			
7	Date of inspection	25.02.2026			
8	Name of the inspecting officers	Rajesh Kumar Shukla, ADO (L.N)			
9	Name of the designation of officer From the building side	Mr. Awdesh, Maintenance Supervisor			
10	Year of construction	2000			
11	Applicant's letter no.	elt.mcdonline application no. 2026021401605			
S. No	Minimum standard of Fire Prevention and Fire Safety U/R 33	Requirement as per Rule 35 (6)	Provide at site	Remarks MR/NMR	
1	Access to Building				
	A	Road width	6.0 m	12.0 m	MR
	B	Gate width	NA	NA	NA
	C	Width of internal roads	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits				
	A	No. of staircase:			
		a) Upper floor	2 nos.	2 nos.	MR
		b) Basements	2 nos.	2 nos.	MR
	B	Width of the staircase:			
		a) Upper floors	1.50 m each	1.50 m each	MR
		b) Basements	1.50 m each	1.50 m each	MR
	C	Protection of exits			
		a) Fire check door	NA	NA	NA
		b) Pressurization	NA	NA	NA
	D	No. of continuous staircase to terrace:	1 no.	2 nos.	MR
	E	Width of the corridor	1.50 m	1.50 m	MR
	F	Door size	1.0 m	1.0 m	MR
3	Compartmentation:				
	A	Fire check doors	NA	NA	NA
	B	Sealing of horizontal & vertical opening	NA	NA	NA
	C	Fire rating of shaft doors	NA	NA	NA
	D	Water curtain	NA	NA	NA
	E	Fire dampers	NA	NA	NA
4	Smoke Management System:				
	A	Basements	Required	Provided	MR
	B	Upper floors	Required	Provided	MR
5	Fire Extinguishers				
	A	Total numbers	8 nos.	10 nos.	MR
	B	Types	CO ₂ , ABC	CO ₂ , ABC	MR
	C	ISI marking	Required	Provided	MR

Rk

6	First Aid Hose Reel				
	A	Total no. at each floor	1 no.	1 no.	MR
	B	Length of hose reel	30 mtrs	30 mtrs	MR
	C	Nozzle diameter	5 mm	5 mm	MR
7	Automatic Fire Detection and Alarm System (ADAS) (Required as per clause 7.31.viii, UBBL 2016).				
	A	Type of detectors	CO detector	Provided	MR
	B	Location of main Panel	Required	Provided	MR
	C	Location of repeater panel	NA	NA	NA
	D	Alternate power source	NA	NA	NA
	E	Hooter's location	Audible in entire building	Provided	MR
8	MOEFA		Required	Provided	MR
9	Public Address System		NA	NA	NA
10	Automatic Sprinkler System				
	A	Basement	Required	Provided	MR
	B	Upper floor	NA	NA	NA
	C	Sprinklers above false ceiling	NA	NA	NA
11	Internal hydrants				
	A	Size of the riser/down comer	NA	NA	NA
	B	No. of hydrants per floor	NA	NA	NA
	C	Hose box	NA	NA	NA
12	Yard Hydrants				
	A	Total no. of hydrants	NA	NA	NA
	B	Hose box	NA	NA	NA
13	Pumpings arrangements				
	A	Ground Level			
		a) Discharge & head of main pump	NA	NA	NA
		b) Number of main pump	NA	NA	NA
		c) Discharge & head of jockey pump	NA	NA	NA
		d) Discharge & head of Standby pump	NA	NA	NA
		e) Auto starting/ manual stopping	NA	NA	NA
	B	Terrace Level			
		a) Discharge of terrace pump	450 LPM	450 LPM	MR
		b) Head of terrace pump	40 m	40 m	MR
		c) Alternate power supply	Required	Provided	MR
		d) Auto starting of pump	Required	Provided	MR
14	Captive Water Storage for Fire Fighting				
	A	Underground tank capacity	NA	NA	NA
	B	Draw off connection	NA	NA	NA
	C	Fire Service Inlet	NA	NA	NA
	E	Access to tank	NA	NA	NA
	D	Overhead tank capacity	20,000 ltrs	20,000 ltrs	MR
15	Exit Signage		Required	Provided	MR
16	Provision of lift				
	A	Pressurization of lift shaft	NA	NA	NA
	B	Pressurization of lift lobby	NA	NA	NA
	C	Communication in lift car	NA	NA	NA
	D	Fireman switch	NA	NA	NA
	E	Lift signage	NA	NA	NA
17	Standby Power Supply		Required	Provided	MR
18	Refuge Area				
	A	location	NA	NA	NA
	B	Total area	NA	NA	NA

M/s Mona International Hotel located at Property no. 196, Patparganj Road, Madhuban, Delhi-92.

19	Fire Control Room			
A	Fire Detection System panel	NA	NA	NA
B	Flow switch panel	NA	NA	NA
C	P A system panel	NA	NA	NA
D	Battery backup	NA	NA	NA
E	Building floor plan	NA	NA	NA
20	Special Fire Protection for special risk if any			
A	NA			NA

LEGENDS:- Meeting Requirement (MR), Not Meeting Requirement (NMR), Not Applicable (NA), Provided but Not Functional (PNF), Not Provided (NP).

The fire protection systems provided in the building were tested, checked at random and found functional at the time of inspections.

In view of the compliance of minimum standards of fire prevention and fire safety measures as required under the Rules, the FSC issued vide letter no. F6/DFS/MS/GH/NDZ/2023/204 dated 27.12.2023 is recommended to be renewed under Rule 37 of the Delhi Fire Service Rules 2010 & last date of disposing of this application is 15.03.2026.

[Signature]
26/2/26

Signature of the Inspecting Officer
Name Rajesh Kumar Shukla
Designation ADO (L.N.)

DO (East) Last date is 15/3/26.

[Signature]
2/3/26

~~Dy. CFO (NDZ)~~

[Signature]
2/3/26

~~Principal Director~~

Dy. CFO to J.S.M.

[Signature]
06/03/26

~~Dy. CFO (NDZ)~~

[Signature]
3/3/26

~~ADOC (NDZ)~~ FI is put up as approved

[Signature]
10/3/26

~~Dy. CFO (NDZ)~~

[Signature]
11/3/26

MS

Uploaded
13/3/26

[Signature]