

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE**  
**NEW DELHI- 110 001**

No. F6/DFS/MS/Hospital/2025/NDZ/ 650

Dated: 11/12/2025

**FIRE SAFETY CERTIFICATE**

Certified that the M/s Monga Medical Centre (A Centre For Personalised Medical Care) located at J-10, Krishna Nagar Delhi 110051, building comprised of Basement, Stilt, Ground plus three Upper Floors only owned/occupied by M/s Monga Medical Centre (A Centre For Personalised Medical Care). The premises was inspected by the officers concerned of this department on 31/10/2025 in the presence of Dr. V.K. Monga and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore complied with rule 33 of Delhi Fire Service Rules, 2010 and that the building/premises is fit for occupancy class "C" 'Institutional Building' with effect from 11/12/2025 for a period of **three** years in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 11/12/2025 at New Delhi by

  
11/12/25

(Dr. S. K. TOMAR)  
DY. CHIEF FIRE OFFICER

Copy to,

1. The Director, M/s Monga Medical Centre (A Centre For Personalised Medical Care) located at J-10, Krishna Nagar Delhi 110051
2. The Directorate of Health Services, M.O. I/C Nursing Home Cell, Govt. of NCT of Delhi, F-17, Karkardooma, Delhi-110032

**Conditions for the validity of Fire Safety Certificate**

1. All the fire safety arrangement provided there in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non-functional fire safety measure shall be at the responsibility of the management.
3. The trained fire-fighter staff should be available round the clock.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. The owner / occupier shall apply for renewal of this Fire Safety Certificate of the Director in Form 'J' [sub rule (1) of rule (37)] along with a copy of this Certificate, Six Months prior to its expiry.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
8. Basement shall be used strictly as per building Bye-Laws.

2/116

1. Name & address of the building : Monga Medical Centre,  
(A Centre For Personalised Medical Care)  
J-10, Krishna Nagar, Delhi-110051
2. Building is comprised of : Basement + stilt + Ground plus three upper floors
3. Type of Occupancy : Institutional (Hospital Building)
4. Type of Case : New
5. Details of Previous FSC letter : Nil
6. Fire Safety directive letter No : F.6/DFS/MS/BP/2022/866 dated 21/04/2022
7. Date of Inspection : 01/12/2025
8. Name of the Inspecting officers : Deepak Kumar, ADO (TP/Shah.)
9. Name and designation of officer from the building side : Dr. V.K. Monga
10. Year of construction : 2020
11. Applicant's letter No : email [mmc.monga@yahoo.com](mailto:mmc.monga@yahoo.com) dt 08/09/2025

Sr. No.	Minimum Standards on Fire Prevention and Fire Safety U/R33	Directive Requirements	Provided at Site	Remarks MR/NMR
01	Access to Building.			
	• Road width	06 mtr.	09mtr.	MR
	• Gate width	N/A	N/A	N/A
	• Width of internal road	N/A	N/A	N/A
02	Number, Width, Type and Arrangement of Exits.			
	a. Number of Staircases			
	• Upper floor	02 nos.	03 nos.	MR
	• Basement	02 nos.	03 nos.	MR
	B. Width of Staircases			
	• Upper floor	2.00 mtr. & 1.50 mtr	1.10 mtr, 2mtr & 1.50 mtr	MR
	• Basement	2.00 mtr. & 1.50 mtr	1.50 mtr & 2mtr	MR
	c. Protection of Exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	N/A	N/A	N/A
	d. No. of Continuous Staircases to Terrace	02 no.	02 no.	MR
	e. Width of Corridor as per plan	1.80 mtr	2.10 mtr	MR
	f. Door Size	2.00 mtr.	2.00 mtr	MR
03	Compartmentation.			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	Required	Provided	MR
	• Fire rating of shaft door	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire dampers	N/A	N/A	N/A
04	Smoke Management System.			
	• Basement	12 a/c per hour	Provided	MR
	• Upper floor	12 a/c per hour	Provided	MR
05.	Fire Extinguishers.			
	• Total numbers	12nos.	20nos.	MR
	• Types	ABC /CO <sub>2</sub>	ABC /CO <sub>2</sub>	MR
	• IS marking	ISI marked	ISI marked	MR

2.

N/A

06	First-Aid-Hose Reels.			
	• Total numbers on each floor	01 No.	02 No.	MR
	• Length of hose reel hose	30 mtr.	30 mtr.	MR
	• Nozzle diameter	05 mm	05 mm	MR
07	Automatic Fire Detection and Alarming System.			
	• Type of detectors	Smoke/Heat	Provided	MR
	• Location of main panel	Ground floor	Provided	MR
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	Required	Provided	MR
	• Hooter's location	N/A	N/A	N/A
08	MOEFA	Required	Provided	MR
09	Public Address System.	Required	Provided	MR
10	Automatic Sprinkler System.			
	• Basement	Required	Provided	MR
	• upper floor	Required	Provided	MR
	• sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• size of riser/down-comer	100 mm	100 mm	MR
	• Number of hydrants per floor	01 no.	01 no.	MR
	• Hose box	01 no.	01 no.	MR
12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose box	N/A	N/A	N/A
13	Pumping Arrangements.			
	➤ Ground Level			
	• Discharge of main pump	1620 lpm	1620 lpm	MR
	• Head of main pump	60 mtr	60 mtr	MR
	• Number of main pumps	01 no.	01 no.	MR
	• Jockey pump out put	180 lpm	180 lpm	MR
	• Jockey pump head	60 mtr	60 mtr	MR
	• Standby pump out put	1620 lpm	1620 lpm	MR
	• Standby pump head	60 mtr	60 mtr	MR
	• Auto starting /manual stopping	Required	Provided	MR
	• Pump house access	Required	Provided	MR
	➤ Terrace Level			
	• Discharge of pump	900 lpm	900 lpm	MR
	• Head of the pump	60 M	60 M	MR
	• Power supply	Required	Provided	MR
	• Auto starting of pump	Required	Provided	MR
14	Captive Water Storage for Fire Fighting.			
	• Underground tank capacity	75,000 ltr.	75,000 ltr.	MR
	• Draw-off connection	Required	Provided	MR
	• Fire service inlet	Required	Provided	MR
	• Access to tank	Required	Provided	MR
	• Overhead tank capacity	10,000 Ltr.	10,000 Ltr.	MR
15	Exit Signage.	Required	Provided	MR



N/18

16	Provision of Lifts.			
	• Pressurization of lift shaft	N/A	N/A	N/A
	• Pressurization of lift lobby	N/A	N/A	N/A
	• Communication in lift car	Required	Provided	MR
	• Firemen's grounding switch	Required	Provided	MR
	• Lift signage	Required	Provided	MR
17	Standby Power Supply	Required	Provided	MR
18	Refuge Area.			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building floor plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if Any:	N/A	N/A	N/A

The fire protection systems provided in the building were randomly tested, checked and found functional at the time of inspection. The earlier shortcomings communicated vide letter no. F.6/DFS/MS/Hospital/2025/NDZ/390 dated 19/08/2025 have been rectified now.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the DFS Rules 2010, if agreed, the Fire Safety Certificate under rule 35 of Delhi Fire Service Rules-2010, is recommended to be issued.

*Deepak*  
21/12/2025

Signature of the Inspecting Officer  
Name :- Deepak Kumar  
Designation :- ADO (Tahirpur)

D.O. (ED) Since the nursing home was operational in 1996. The building parameters are taken as per BBL-1983.

*[Signature]*  
6/12/25

Dy. CFO (NDZ)

*[Signature]*  
8/12/25

Principal Director

Dy. CFO to [Signature]

*[Signature]*  
09/12/25

Dy. CFO (NDZ)

*[Signature]*  
11/12/25

ADO (FP)