



**FIRE SAFETY CERTIFICATE**

Certified that the **Mother Foundation School** located at **13A, Gali No. 10 Molarband Extn, Badarpur, New Delhi**, was granted No Objection Certificate (NOC) by this department vide letter no.- F6/DFS/MS/2007/2355 dated 24.08.2007 for Basement (Vacant as per affidavit submitted) & ground floor only in a building Basement + Ground floor only. The school building was re-inspected by Assistant Divisional Officer (M. Road) from this department on 05.05.2025 in the presence of Mr. Harish Kumar (Manager) and found that the school building is comprised of Basement (Vacant, as per Affidavit submitted) + Ground +01 upper floor. The school has deemed complied with the fire prevention and fire safety requirements in accordance with the circular no. 262-362 dated-17/01/2005 issued by the Directorate of Education and the building (**Ground + 01 upper floor**) is fit for occupancy of Group B "Educational Building" with effect from 13/05/2025 renewed for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to conditions under Rule 38 of Delhi Fire Service Rules, 2010 printed below.

Issued on...13/05/2025.....at New Delhi by

  
(Atul Garg)  
Director  
Delhi Fire Service

**Copy to:-**

1. The Dy. Director of Education, GNCT of New Delhi DISST. South Block-C, Defence Colony, New Delhi-24.
2. The Principal, Mother Foundation School located at 13A, Gali No. 10 Molarband Extn, Badarpur, New Delhi.

**Conditions for the validity of Fire Safety Certificate**

1. **This Fire Safety Certificate is valid for Ground +01 upper floor only.**
2. All the means of escape shall be kept free of all the type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
5. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
6. This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
8. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form J' [sub Rule (1) of Rule 37] along with a copy of this certificate, six months prior to its expiry.
9. Approach to the terrace is available in case of emergency.

2/8  
**INSPECTION REPORT**

1	Name & address of the building	Mother Foundation School located at 13A, Gali No. 10 Molarband Extn, Badarpur, New Delhi.		
2	Building is comprised of	Basement (vacant as per Affidavit submitted) + Ground + 01 upper floors		
3	Type of occupancy	Group B –Educational Building		
4	Type of case	Renewal/addition of 1 <sup>st</sup> floor of the existing building		
5	Details of previous NOC	F6/DFS/MS/2007/2355 dated 24.08.2007 for ground floor only.		
6	Fire safety direction letter no.	DOE Circular no. 262-362 dated 17.01.2005		
7	Date of inspection	05.05.2025		
8	Name of the inspecting officers	Rajesh Kumar Shukla, ADO (M. Road)		
9	Name of the designation of officer from the building side	Mr. Harish Kumar (Manager)		
10	Year of construction	2007-2010		
11	Applicant's letter no.	Outdoor diary no. 14994 dated 26.03.2025		
S.No	Minimum standard of fire prevention and fire safety U/R 33	Requirement as per Rules 35 (6)	Provided at site	Remarks MR/NMR
1	<b>Access to Building:</b>			
A	Road width	Accessible	Accessible	MR
B	Gate width	NA	NA	NA
C	Width of internal road	NA	NA	NA
2	<b>Number, Width, Type and Arrangement of Exits:</b>			
A	Number of staircases			
a	Upper floor	02 nos.	02 nos.	MR
b	Basement	NA	NA	NA
B	Width of staircases			
a	Upper floor	2 nos. (Exits).	1.50 mtrs (Iron) & 1.20 mtrs	MR
b	Basement	2 nos. (Exits).	1.50 mtrs (Iron) & 0.93 mtrs	MR
C	Protection of exits		NA	NA
a	Fire check door	NA	NA	NA
b	Pressurization	NA	NA	NA
D	No. of continuous staircases to terrace	Required	01 no.	MR
E	Width of corridor	NA	NA	NA
F	Door size	1.0 mtrs. (for class room)	Provided	MR
3	<b>Compartmentation:</b>			
A	Fire check door	NA	NA	NA
B	Sealing of electrical shafts	NA	NA	NA
C	Fire rating of shaft door	NA	NA	NA
D	Water curtain	NA	NA	NA
E	Fire dampers	NA	NA	NA
4	<b>Smoke Management System:</b>			
A	Basement	NA	NA	NA
B	Upper floor	NA	NA	NA
5.	<b>Fire Extinguisher:</b>			
A	Total numbers	06 nos.	06 nos.	MR
B	Types	CO <sub>2</sub> & ABC	CO <sub>2</sub> & ABC	MR
C	ISI marking	Required	Provided	MR
6	<b>First-Aid-Hose Reel:</b>			
A	Total numbers of each floor	01 no.	01 no.	MR
B	Length of hose reel hose	30 mtrs	30 mtrs	MR
C	Nozzle diameter	5 mm	5 mm	MR

<b>7</b>	<b>Automatic Fire Detection and Alarming System:</b>				
	<b>A</b>	Type of detectors	NA	NA	NA
	<b>B</b>	Location of main panel	NA	NA	NA
	<b>C</b>	Location of repeater panel	NA	NA	NA
	<b>D</b>	Alternate source of power	NA	NA	NA
	<b>E</b>	Hooters	NA	NA	NA
<b>8</b>	<b>MOEFA:</b>		NA	NA	NA
<b>9</b>	<b>Public Address System:</b>		NA	NA	NA
<b>10</b>	<b>Automatic Sprinkler System:</b>				
	<b>A</b>	Basement (Area below 200 Sqm)	NA	NA	NA
	<b>B</b>	Upper floor	NA	NA	NA
	<b>C</b>	Sprinkler above false ceiling	NA	NA	NA
<b>11</b>	<b>Internal Hydrants:</b>				
	<b>A</b>	Size of riser/down-comer	NA	NA	NA
	<b>B</b>	Number of hydrants per floor	NA	NA	NA
	<b>C</b>	Hose box	NA	NA	NA
<b>12</b>	<b>Yard Hydrants:</b>				
	<b>A</b>	Total number of hydrants	NA	NA	NA
	<b>B</b>	Hose box	NA	NA	NA
<b>13</b>	<b>Pumping Arrangements:</b>				
<b>A</b>	<b>Ground level</b>				
	<b>a</b>	Discharge of main pump	NA	NA	NA
	<b>b</b>	Head of main pump	NA	NA	NA
	<b>c</b>	Number of main pumps	NA	NA	NA
	<b>d</b>	Jockey pump out put	NA	NA	NA
	<b>e</b>	Jockey pump head	NA	NA	NA
	<b>f</b>	Standby pump out put	NA	NA	NA
	<b>g</b>	Standby pump head	NA	NA	NA
	<b>h</b>	Auto starting /manual stopping	NA	NA	NA
	<b>i</b>	Pump house access	NA	NA	NA
<b>B</b>	<b>Terrace Level</b>				
	<b>a</b>	Discharge of pump	220 LPM	Provided	MR
	<b>b</b>	Head of the pump	30 mtrs	Provided	MR
	<b>c</b>	Power supply	Required	Provided	MR
	<b>d</b>	Auto starting of pump	Required	Provided	MR
<b>14</b>	<b>Captive Water Storage for Fire Fighting:</b>				
	<b>A</b>	Underground tank capacity	NA	NA	NA
	<b>B</b>	Draw-off connection	NA	NA	NA
	<b>C</b>	Fire service inlet	NA	NA	NA
	<b>D</b>	Access to tank	NA	NA	NA
	<b>E</b>	Overhead tank capacity	2,500 liters	Provided	MR
<b>15</b>	<b>Exit Signage:</b>		Required	Provided	MR
<b>16</b>	<b>Provision of Lifts:</b>				
	<b>A</b>	Pressurization of lift shaft	NA	NA	NA
	<b>B</b>	Pressurization of lift lobby	NA	NA	NA
	<b>C</b>	Communication in lift car	NA	NA	NA
	<b>D</b>	Firemen's grounding switch	NA	NA	NA
	<b>E</b>	Lift signage	NA	NA	NA
<b>17</b>	<b>Standby Power Supply:</b>		NA	NA	NA
<b>18</b>	<b>Refuge Area:</b>				
	<b>A</b>	Total area	NA	NA	NA
	<b>B</b>	Location	NA	NA	NA


<b>19 Fire Control Room:</b>				
A	Detector system panel	NA	NA	NA
B	Flow switch panel	NA	NA	NA
C	PA system panel	NA	NA	NA
D	Battery backup	NA	NA	NA
E	Building floor plans	NA	NA	NA
20	Special Fire Protection systems for protection of special Risks, if any:	NA		NA

**Meeting Requirement (MR), Not Meeting Requirement (NMR), Not Applicable (NA), Provided but Not Functional (PNF), Not Provided (NP).**



**Note:** During previous inspection the building is comprised of Basement + Ground floor only now the building is comprised of Basement + Ground floor + 01 upper floor & school running on Ground + 01 upper floor only.

The fire protection systems provided in the building were tested, checked at random and found functional at the time of inspections.

If agreed to the note above & in view of the deemed compliance of minimum standards of fire prevention and fire safety measures as required in Directorate of Education Circular 262-362 Dated-17/01/2005, the FSC issued vide letter no. F6/DFS/MS/2007/2355 dated 24.08.2007 is recommended to be renewed.

  
 Signature of the Inspecting Officer  
 Name Rajesh Kumar Shukla  
 Designation ADO (M. Road)

DO (SD) 

  
  
 Director 