

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**



No. F.6/DFS/MS/School/2025/NDZ/ 1397

Dated: 16 / 12 / 2025

**FIRE SAFETY CERTIFICATE**

Certified that **Motherhood Public School** located at C-147, Street No. 06, New Usman Pur, Delhi-110053, comprised of ground plus three upper floors, owned/occupied by Motherhood Public School was issued FSC vide letter no. F.6/DFS/MS/School/2022/NDZ/169 dated 15/02/2022. The premises was re-inspected by the officer concerned of this department on 24/11/2025 in the presence Sh. Vipul Tiwari (Manager) and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with rule 33 of Delhi Fire Service Rules 2010 and that the premises is fit for occupancy class "Educational" (Group-B) with effect from 16 / 12 / 2025 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rules, 2010 & also conditions printed below.

Issued on 16 / 12 / 2025 at New Delhi by



(Dr. S. K. TOMAR)  
 DY. CHIEF FIRE OFFICER  
 DELHI FIRE SERVICE

Copy to: -

1. The Principal, Motherhood Public School, C-147, Street No. 06, New Usman Pur, Delhi-110053.
2. The Commissioner, MCD, H Qtrs., Dr. S.P Marg, Civic Center, Minto Road, New Delhi-110002.

**Conditions for the validity of Fire Safety Certificate:-**

1. All the means of escape / entry / exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working conditions at all times. Any loss of life or property due to non-functional fire safety measure shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
4. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3. of UBBL-2016), if any.
5. The owner/occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".

## INSPECTION REPORT

1.	Name & address of the building	Motherhood Public School, C-147, Street No. 06, New Usman Pur, Delhi-110053.		
2.	Building is comprised of	Ground plus three upper floors.		
3.	Type of Occupancy	Educational Group-B (School)		
4.	Type of Case	Renewal		
5.	Details of Previous NOC letter	F.6/DFS/MS/School/2022/NDZ/169 dt. 15/02/2022		
6.	Fire Safety directive letter No	NBC Part -IV		
7.	Date of Inspection	24/11/2025		
8.	Name of the Inspecting officers	Deepak Kumar, ADO (Tahirpur)		
9.	Name and designation of Officer from the building side	Sh. Vipul Tiwari (Manager)		
10.	Year of Construction	2017		
11.	Applicant's letter received through	Email Id- <a href="mailto:vipultiwari41@gmail.com">vipultiwari41@gmail.com</a> dated 12/11/2025		
Sr. No	Minimum Standards on fire prevention and fire safety U/R33	NBC Part-IV Requirements	Provided at Site	Remarks MR/NMR
01	Access to building.			
	<ul style="list-style-type: none"> <li>Road with</li> </ul>	06 mtr	06 mtr	MR (accepted earlier) 01 length of hose
	<ul style="list-style-type: none"> <li>Gate width</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Width of internal road</li> </ul>	N/A	N/A	N/A
02	Number, Width, Type and Arrangement of Exits.			
	a. Number of Staircases			
	<ul style="list-style-type: none"> <li>Upper Floor</li> </ul>	01 Nos.	02 Nos.	MR
	<ul style="list-style-type: none"> <li>Basement</li> </ul>	N/A	N/A	N/A
	b. Width of Staircases			
	<ul style="list-style-type: none"> <li>Upper Floor</li> </ul>	1.50 mtr.	1.51 mtr & 1.24 mtr.	MR
	<ul style="list-style-type: none"> <li>Basement</li> </ul>	N/A	N/A	N/A
	c. Protection of exits			
	<ul style="list-style-type: none"> <li>Fire check door</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Pressurization</li> </ul>	N/A	N/A	N/A
	d. No. of continuous staircases to terrace	02 Nos.	02 Nos.	MR
	e. Width of Corridor	1.50 mtr.	1.50 mtr.	MR
	f. Door Size	01 mtr.	01 mtr.	MR
03	Compartmentation.			
	<ul style="list-style-type: none"> <li>Fire check door</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Sealing of electrical shafts</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Fire rating of shaft door</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Water curtain</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Fire Dampers</li> </ul>	N/A	N/A	N/A
04	Smoke Management System.			
	<ul style="list-style-type: none"> <li>Basement</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Upper floor</li> </ul>	N/A	N/A	N/A
05.	Fire Extinguishers.			
	<ul style="list-style-type: none"> <li>Total numbers</li> </ul>	10 Nos.	10 Nos	MR
	<ul style="list-style-type: none"> <li>Types</li> </ul>	ABC / CO <sub>2</sub>	ABC & CO <sub>2</sub>	MR
	<ul style="list-style-type: none"> <li>ISI marking</li> </ul>	ISI marked	Provided	MR

2.

06	First-aid-Hose Reels.	01	01	MR
	• Total numbers on each floor	30 mtr	30 mtr	MR
	• Length of hose reel hose	05 mm	05 mm	MR
	• Nozzle diameter			
07	Automatic fire detection and alarming system.	N/A	N/A	N/A
	• Type of detectors	N/A	N/A	N/A
	• Location of main panel	N/A	N/A	N/A
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter's location	N/A	N/A	N/A
08	MOEFA	N/A	N/A	N/A
09	Public address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.			
	• Basement	N/A	N/A	N/A
	• upper floor	N/A	N/A	N/A
	• sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• Size of riser/down-comer	N/A	N/A	N/A
	• Number of hydrants per floor	N/A	01	N/A
	• Hose Box	N/A	01	N/A
12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13	Pumping Arrangements.			
	➤ Ground Level	N/A	N/A	N/A
	• Discharge of main Pump	N/A	N/A	N/A
	• Head of Main Pump	N/A	N/A	N/A
	• Number of main pumps	N/A	N/A	N/A
	• Jockey pump out put	N/A	N/A	N/A
	• Jockey pump head	N/A	N/A	N/A
	• Standby pump out put	N/A	N/A	N/A
	• Standby pump Head	N/A	N/A	N/A
	• Auto Starting /Manual stopping	N/A	N/A	N/A
	• Pump House Access	N/A	N/A	N/A
	➤ Terrace Level			
	• Discharge of pump	450 Lpm	450 Lpm	MR
	• Head of the Pump	40 mtr.	40 mtr.	MR
	• Power supply	Required	Provided	MR
	• Auto Starting of pump	Required	Required	MR
14	Captive Water Storage for Fire Fighting.			
	• Underground tank capacity	N/A	N/A	N/A
	• Draw-off connection	N/A	N/A	N/A
	• Fire service inlet	N/A	N/A	N/A
	• Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	10,000 Ltrs.	10,000 Ltrs.	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A

17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building/premises were checked, tested at random and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the NBC Part-IV rules, the fire safety certificate issued vide letter No. F.6/DFS/MS/School/2022/170 dated 15/02/2022, **renewal under rule 37 of the Delhi Fire Service Rules, 2010 is recommended.**

*Deepak*  
28/11/2025  
Signature of the Inspecting Officer  
Name :- Deepak Kumar  
Designation :- A.D.O (Tahirpur)

DO(ED)  
*[Signature]* 28/11/20

Dy. CTO (ASMA)

*[Signature]*  
01/12/2022  
Principal Director

Dy. CTO to DGM -  
*[Signature]*  
02/12/22

Dy. CTO (NDZ)

*[Signature]*  
3/12/22

ADO (TP)  
Sir, F.T. letter is put up for your kind  
signature pl.

Dy. CTO (NDZ)

*[Signature]*  
8/12/22

*Deepak*  
05/12/2022

ms