

217

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110 001.

No. F.6/DFS/MS/School/2025/SZ/ 233

Dated: 11/03/2025

FIRE SAFETY CERTIFICATE

Certified that the **MRS Global School (Junior Wing)** running at ground floor in a building comprised of basement (store & office/others property), ground, upper ground plus three upper floors at Plot No. 2 & 3, Kh. No. 7/5, GF, Pillar No. 811, Main Najafgarh Road, Hari Vihar, New Delhi-110078, owned/occupied by **MRS Global School**. The school building was inspected by the officer concerned of this department on dated 03.03.2025 in the presence of Mr. R.K. Yadav, and found that the building/ premises is fit for occupancy class B 'Educational Building' (for ground floor only) w.e.f. 11/03/2025 for a period of three years in accordance with the Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010, printed below. Issued on 11/03/2025 at New Delhi.

(Atul Garg)
Director

Delhi Fire Service

Copy to: -

1. The Commissioner, MCD, Delhi: for information regarding use of basement and to ensure the occupancy as detailed above and deviation, if any.
2. The Principal, MRS Global School (Junior Wing) at Plot No. 2 & 3, Kh. No. 7/5, GF, Pillar No. 811, Main Najafgarh Road, Hari Vihar, New Delhi-110078.
2. Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi - 110054.

Conditions for validity of fire safety certificate: -

1. **The FSC issued only for ground floor.**
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
3. The means of escape shall be kept unlocked and unobstructed for unhindered evacuation of occupants in case of emergency.
4. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
5. The trained staff should be available round the clock.
6. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
7. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
8. Basement strictly shall be used as per BBL.
9. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
10. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

N/1

INSPECTION REPORT

1. Name & address of the building : MRS Global School kl(Junior Wing) at Plot No. 2 & 3, Kh. No. 7/5, GF, Pillar No. 811, Main Najafgarh Road Hari Vihar, New Delhi-110078.
2. Building is comprised of : B, G+3 upper floors (school running at ground floor only) .
3. Type of Occupancy : Educational
4. Type of Case : New
5. Details of Previous NOC : N/A
6. Fire Safety directives letter No : NBC Part-IV
7. Date of inspection : 03.03.2025
8. Name of Inspecting Officer : A.D.O. R.K. Yadav
9. Name and designation of officers
From the building side : Mr. R.K. Yadav (Manager)
10. Year of Construction : 2005
11. Applicant's letter No. : Online email Id mrstestingservices@gmail.com dated 06.11.2024

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	Accessible 06 m 4.5 m N/A	06 m Directly accessible from road N/A	MR MR N/A
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	N/A	N/A	N/A
	• Basements	N/A	N/A	N/A
	b. Width of staircases			
	• Upper Floor	N/A	N/A	N/A
	• Basements	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No. of continuous staircases to terrace	N/A	N/A	N/A
	e. Width of Corridor	N/A	N/A	N/A
	f. Door Size	1.20 m	1.20 m	MR
3.	Compartmentation			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	• Basements	N/A	N/A	N/A
	• Upper floors	Required	Natural ventilation provided	MR
5.	Fire Extinguishers			
	• Total numbers	08 no's	Provided	MR
	• Types	ABC/CO ₂ type	Provided	MR
	• IS marking	ISI marked	Provided	MR
6.	First-Aid Hose Reels			
	• Total numbers on each floor	N/A	N/A	N/A
	• Length of hose reel hose	N/A	N/A	N/A
	• Nozzle diameter	N/A	N/A	N/A

15

4

N/3

17.	Standby power supply	N/A	N/A	N/A
18.	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19.	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were test checked and found not functional at the time of inspection.

Keeping in view of the above compliance of the minimum standards of fire prevention and fire safety measures under Rule 35 of the Delhi Fire Service Rules 2010, it's recommended to grant Fire Safety Certificate.

Note: - As per the undertaking given by the school management (placed at C-7) that the school running at ground floor in a building comprised of basement (store & office), ground floor (school), upper ground, first & second floor (CBT online computer lab) and third floor (residence half area). Hight of the building is 14.96 m from highest road level outside building upto top of the RCC roof slab of fourth floor.

R.K. Yadav
21/2/2025

Signature of the Inspecting Officer
Name- R.K. Yadav
Designation- ADO (JKP)

DO (South West)

[Signature]
5/3/25

[Signature]
6/3/2025

Director

[Signature]
6/3/25

[Signature]