

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No. F6/DFS/MS/School/WZ/2025/ 546

Dated: 24/04/2025

FIRE SAFETY CERTIFICATE

Certified that the Muni Maya Ram Jain Model School, located at 2nd Floor & 3rd floor, 2541, Jain DharamShala, Jain Sathanak Marg, Tri Nagar, Delhi-110035, in a building is comprised of Ground + 03 Upper Floors, owned/occupier by Muni Maya Ram Jain Model School, was issued FSC vide letter No F6/DFS/MS/School/WZ/2018/2255 dated 05/10/2018. The premises was re - inspected by the officer concerned by this department on 29/03/2025 in the presence of Ms. Renu Arora and observed that all the fire prevention & fire safety arrangements provided in the premises found in good working condition. The building/premises have deemed complied with fire prevention and fire safety requirements in accordance with DOE Circular No.262-362 dated 17/01/2005 and the building/ premises is fit for occupancy class "Educational" (Group -B) (2nd floor & 3rd floor only) with effect from 24/04/2025.. for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010. Condition mentioned below

Issued on 24/04/2025 at New Delhi.

(Atul Garg)
Director

Copy to:

1. Director of Education, GNCT of NCT of Delhi, Old Secretariat, Delhi 110054.
2. The Principal, Muni Maya Ram Jain Model School, located at 2nd Floor & 3rd Floor, 2541, Jain Dharam Shala, Jain Sathanak Marg, Tri Nagar, Delhi-110035.

Conditions for the validity of FSC:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. All the means of escapes/exits shall not be locked/blocked at any time for safe evacuation of the occupants in case of emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

1. Name & address of the building	Muni Maya Ram Jain Model School, located at 2 nd Floor & 3 rd Floor, 2541, Jain Dharam Shala, Jain Sathanak Marg, Tri Nagar, Delhi-110035.
2. Type of Occupancy	Educational (Ground + 03 Upper Floors)
3. Type of Case	Renewal
4. Details of previous NOC	F6/DFS/MS/School/WZ/2018/2255 dated 05/10/2018.
5. Fire Safety directives letter No	DOE Circular No.262-362 dated 17/01/2005
6. Date of inspection	29/03/2025
7. Name of the Inspecting Officers	Sarabjeet Singh ADO (MN)
8. Name and designation of officers from the building side	Ms. Renu Arora (Principal)
9. Year of Construction	1989 (As per previous Inspection Report dated 18/09/2018)
10. Applicant's letter No.	Outdoor Dairy No.14947 dated 25/03/2025

The said school is running at 2nd Floor & 3rd Floor, in a building is comprised of Ground + 03 Upper Floors, was issued FSC vide letter No F6/DFS/MS/School/WZ/2018/2255 dated 05/10/2018.

S. No	Minimum Standards on fire prevention and fire safety U/R 33	As per Rule 35 (6) DFS Rule 2010	Provided at site	Remarks
1	Access to building			MR/NMR
	<ul style="list-style-type: none"> Road width Gate width Width of internal road 	<ul style="list-style-type: none"> Accessible Accessible NA 	<ul style="list-style-type: none"> 6 m Provided Provided on Road NA 	<ul style="list-style-type: none"> MR MR NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> Upper Floors Basements 	<ul style="list-style-type: none"> 01 NA 	<ul style="list-style-type: none"> 02 Provided NA 	<ul style="list-style-type: none"> MR NA
	b. Width of staircases			
	<ul style="list-style-type: none"> Upper Floors Basements 	<ul style="list-style-type: none"> 1 x 1.5 mtrs NA 	<ul style="list-style-type: none"> Provided 1 x 114 cm & 1 x 95 cm NA 	<ul style="list-style-type: none"> MR old case NA
	c. Protection of exits			
	<ul style="list-style-type: none"> Fire check door Pressurization 	<ul style="list-style-type: none"> NA NA 	<ul style="list-style-type: none"> NA NA 	<ul style="list-style-type: none"> NA NA
	d. No. of continuous staircases to terrace	01	Provided	MR
	e. Width of Corridor	Required	160 cm Provided	MR
	f. Door Size	1 m	98 cm (old case)	MR old case
3	Compartmentation.			
	<ul style="list-style-type: none"> Fire check door Sealing of electrical shafts Fire Rating of shaft door Water Curtain Fire Dampers 	<ul style="list-style-type: none"> NA NA NA NA NA 	<ul style="list-style-type: none"> NA NA NA NA NA 	<ul style="list-style-type: none"> NA NA NA NA NA
4	Smoke Management System.			
	<ul style="list-style-type: none"> Basements Upper floors 	<ul style="list-style-type: none"> NA NA 	<ul style="list-style-type: none"> NA NA 	<ul style="list-style-type: none"> NA NA
5	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types IS marking 	<ul style="list-style-type: none"> 04 nos. CO₂, ABC type ISI marked 	<ul style="list-style-type: none"> Provided Provided Provided 	<ul style="list-style-type: none"> MR MR MR
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> Total numbers on each floor 	<ul style="list-style-type: none"> 01 30 mts 	<ul style="list-style-type: none"> Provided Provided 	<ul style="list-style-type: none"> MR MR

	<ul style="list-style-type: none"> Length of hose reel hose Nozzle diameter 	05 mm	Provided	MR
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
8	MOEFA	Required	Provided	MR
9	Public Address System.	Required	Provided	MR
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> Basement Upper Floor Sprinkler above false ceiling 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
11	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	01	Provided	MR
		01	Provided	MR
		01	Provided	MR
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	NA	NA	NA
		NA	NA	NA
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/ Manual stopping Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 			
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		450 LPM & 180 LPM	Provided	MR
		40 mtrs	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
14	Captive Water Storage for fire fighting.			
	<ul style="list-style-type: none"> Underground tank capacity <ul style="list-style-type: none"> Draw-off connection Fire service inlet Access to tank Overhead Tank capacity 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		5,000 lts	Provided	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of Lift Shaft Pressurization of Lift lobby 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA

		• Communication In lift Car	NA	NA	NA
		• Fireman's Grounding Switch	NA	NA	NA
		• Lift Signage	NA	NA	NA
MR	17	Standby power supply	NA	NA	NA
	18	Refuge Area.			
		➤ Total Area	NA	NA	NA
		➤ Location	NA	NA	NA
	19	Fire Control Room			
NA		• Detector System Panel	NA	NA	NA
NA		• Flow Switch Panel	NA	NA	NA
NA		• PA System Panel	NA	NA	NA
MR		• Battery backup	NA	NA	NA
MR		• Building Floor Plans	NA	NA	NA
	20	Special Fire Protection Systems for Protection of special Risks, if any:	NA	NA	NA

The fire protection systems provided in the building were checked and found functional at the time of inspection.

Keeping in view of the deemed compliance of minimum standards of fire prevention and fire safety measures as required under the rules, the NOC vide letter no F6/DFS/MS/School/WZ/2022/366 dated 04/04/2022, renewal under DOE Circular No.262-362 dated 17/01/2005 is recommended.

133/ADO/MN
01/04/2025

[Signature]
04/04/2025

[Signature]
01/04/2025

Signature of the Inspecting Officer
Sarabjeet Singh ADO (MN)

635WP
3/4/2025

[Signature]
03/4/2025

[Signature]
4/4/2025

[Signature]
AD/MN

Sir R.T is put up for your kind personal & signature pls
[Signature]
22/4/2025