



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001**

No.F.6/DFS/MS/EH/SZ/2025/ 566

Dated: 28/11/2025

To,

Sh. Amit Rekhi,
M/s Music & Mountain
J-2/12, 2nd Floor, Rajouri Garden,
New Delhi-110027

**Subject:-Regarding renewal of Fire Safety Certificate in r/o M/s Music & Mountain located at
M-23, 2nd floor, Greater Kailash, New Delhi-110048.**

Sir,

This has reference to your MCD online application ID No. **2025102814416** dated 29/10/2025 on the subject cited above. In this connection, it is to inform you that the premises was visited by the officer concerned of this department on dated 12/11/2025 in presence of Sh. Amit Rekhi (Building Owner). The premises is comprised of Basement, Ground plus three upper floors only. The following shortcoming was observed during the time of inspection.

1. The required Fire Check Doors for compartmentation and protection of Exit found removed.

In view of above shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire Safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(A. K. MALIK)
DY. CHIEF FIRE OFFICER
DELHI FIRE SERVICE

MCD online ID :- 2025102814416