

c/sr

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001

No.F.6/DFS/MS/2025/165

Dated 16/04/2025

To,

Sh. Upma Saxena,
Deputy General Manager,
NABARD, 24, Rajindra Place, New Delhi.

Sub:- Regarding renewal of FSC in r/o NABARD, 24, Rajindra Place, New Delhi.

Sir,

This has reference to your letter no. NB.ND/Fire Safety/156422/2024-25 dated 04.03.2025, on the subject cited above. In this connection it is to inform that the site was visited by the officers concerned of this department on 03/04/2025 in the presence of Sh. Manish Gupta, and the following shortcomings were observed:-

1. Fire checks door found removed with normal door at 7th floor.
2. Electrical shaft required to be sealed properly.
3. Detectors found nonfunctional at some office.
4. Smoke management system found non functional in basement and also not integrated with alarm system .

In view of above case is rejected with a request to rectify the above shortcomings at the earliest for further consideration in the matter. Further, the occupancy of the building/premises in absence of requisite fire safety arrangements shall be at risk and liability of owner/occupier. The licensing /statuary authority may take suitable necessary action as deemed fit.

Yours faithfully


16/4/2025
(Virendra Singh)
Chief Fire Officer
Delhi Fire Service

