



C-12

75
आज़ादी का
अमृत महोत्सव

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, NEW DELHI

No. F6/DFS/MS/EH/2026/ 878

Dated: 16 / 09 /2026

To,

The Commissioner MCD,
Civic Centre, Minto Road,
New Delhi- 110002.

Sub: Regarding issuance of FSC from fire safety point of view in respect of M/s. NAM (A Unit of Hidden Naam Hospitality LLP) located at E-22, Ground Floor, Hauz Khas Main Market, New Delhi-110016.


Sir,

Please refer to your online application ID No. 2026072510109 dated-26/07/2026, on the subject cited above. In this connection, it is to inform you that the premise was inspected by officer concerned of this department on 17/08/2026 in the presence of Sh. Rudra Pratap Singh to see the functioning of fire safety arrangements/equipments provided in the building. During inspection the following shortcomings were observed.

1. First-Aid hose reels not provided.
2. Main Fire Pump capacity of 450 LPM is not provided.
3. Overhead tank capacity of 20,000 ltrs. is not provided.
4. Exit signage's not provided.

In view of above, the application for issuance of Fire safety Certificate is cannot consider at this stage.

Yours faithfully,


(A.K. Malik)
Chief Fire Officer

Copy To: -

1. The Owner/occupier, M/s. NAM (A Unit of Hidden Naam Hospitality LLP) located at E-22, Ground Floor, Hauz Khas Main Market, New Delhi-110016. (Online application No. 2026072510109 dated-26/07/2026).