

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

C-18
75
आजादी का
अमृत महोत्सव

No. F6/DFS/MS/NDZ/2026/ 182

Dated: - 26/02/2026

To,

The Commissioner,
Municipal Corporation of Delhi,
Civic Centre, Minto Road,
New Delhi -110002.

Subject: Regarding issuance of Fire Safety Certificate in respect of M/s. Nathu Sweets, located at 1963/2 Ground Floor, Kh. No. 379, Railway Road, Pana Udyan, Main Bazar Narela, Delhi-110040.

Sir,

Please refer to online application no. 2026012400864 dated 24/01/2026, on the subject cited above. In this regard, it is to inform you that the above said restaurant was inspected by the officer concerned of this department on 05/02/2026 in the presence of Sh. Rajeev Gupta (Owner). During inspection, it has been observed that the said restaurant is running on ground floor only and the building is comprised of ground + two upper floors + Tin Shed on terrace floor. However, the following shortcomings have been observed:-

1. Door widths of both exit doors are less than required width of 1.5 m.
2. Smoke Management System is not provided.
3. MOEFA is not provided.
4. Internal Hydrants is not provided.
5. Fire pump of 450 lpm capacity is provided but not on auto operation.
6. 2,000 ltrs capacity overhead water storage tank is provided against required capacity of 20,000 ltrs.
7. Exit signage is not provided.

In view of the above shortcomings, the application for issuance of Fire Safety Certificate cannot be considered at this stage & rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing Authority/statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

S.K. Dua
25/02/26

S.K. Dua

Dy. Chief Fire Officer (WZ)
Delhi Fire Service

S.K. Dua
25/02/26

Copy to:-

1. The Authorized Signatory, M/s. Nathu Sweets, located at 1963/2, Ground Floor, Kh. No. 379, Railway Road, Pana Udyan, Main Bazar Narela, Delhi-110040.