

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

75
आज़ादी का
अमृत महोत्सव

No. F6/DFS/MS/NDZ/2026/ 70

Dated: -12/03/2026

To,
The Commissioner,
Municipal Corporation of Delhi,
Civic Centre, Minto Road,
New Delhi - 110001.

Sub: Regarding renewal of FSC in r/o National Council YMCA, Bharat Yuvak Bhawan at Jai Singh Road, New Delhi.

Sir,

Please refer your online application No. 2026021101491 dated 11.02.2026, on the subject cited above. In this connection, it is to inform you that the said building was inspected by the officers concerned of this department on 26/02/2026 in the presence of Sh. P Babu, Property Manager & Sh. Ashish Thorat, Secretary (Finance & Admin) and following shortcomings were observed: -

1. Underground Water Storage tank of 2,00,000 Ltrs capacity is provided against the required capacity of 3,00,000 Ltrs and overhead water storage tank of 30,000 Ltrs capacity is provided against the required capacity of 50,000 Ltrs.
2. Refuge area found removed at 3rd floor.

In view of the above shortcomings, the application for renewal of fire safety certificate cannot be considered at this stage & stands rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,



(Dr. S. K. Tomar)

Dy. Chief fire Officer
Delhi Fire Service

Copy To: -

1. The Secretary (Finance & Admin), National Council YMCA, Bharat Yuvak Bhawan, Jai Singh Road, New Delhi - 110001.