

C-83



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001



No: F.6/DFS/MS/GH/2025/NDZ/179

Dated: 17/04/25

To,

The Joint Commissioner of Police,  
Licensing Unit, 1<sup>st</sup> Floor,  
Police Station, Defence Colony,  
New Delhi.

Sub: -Regarding renewal of Fire Safety Certificate in r/o Navyug Guest House,  
located at 2322-2324, Bahadurgarh Road, Teliwara, Delhi- 110006.

Sir,

This has reference to online application received through MCD portal vide ID- 2025031904007, on the subject cited above. In this connection, it is to inform you that the above said residential building was re-inspected by officer concerned of this department on 05/04/2025 to see the compliance of requisite fire safety measures. Sh. Nirmal Gulati was present at the time of inspection. Following shortcoming were observed at the time of inspection.

1. Fire check doors not provided.
2. Carbon monoxide detectors not provided.
3. Exit signage's found removed.

In view of above, the application for renewal of Fire Safety Certificate is not considered at this stage & rejected. The occupancy of the building/ premises in absence of requisites fire safety measures shall be at the risk and liabilities of the owner/ occupier.

Yours Faithfully

(Atul Garg)  
Director

Ph. 011-23414000



Copy to:-

1. The owner/ occupier, M/s Navyug Guest House located at 2322- 2324, Bahadurgarh Road, Teliwara, Delhi- 110006.
2. MCD Portal ID No. 2025031904007.