

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

75  
आजादी का  
अमृत महोत्सव

No. F6/DFS/MS/School/WZ/2026/ 27

Dated:- 06/03/2026

**FIRE SAFETY CERTIFICATE**

Certified that the New Daffodil Public School, located at Gali No. 5, Prem Colony, Bawana Road, Narela, Delhi-110040, comprised of Ground + 03 Upper Floors only, owned/occupied by New Daffodil Public School have complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rule, 2010 and verified by the officer concerned of Fire Service on 26/02/2026 in the presence of Sh. R.P. Tyagi (Owner) and that the building/premises is fit for occupancy class " Educational Building" Group B with effect from 06/03/2026 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010, printed below.

Issued on 06/03/2026 at New Delhi by

*R.P. Tyagi*  
06/03/26  
S.K. Dua

Dy. Chief Fire Officer (WZ)  
Delhi Fire Service

*Pr. 87C*  
06/03/26

Copy to:-

1. The Director, Directorate of Education, GNCT of Delhi, Old Secretariat Delhi – 110054.
2. The Principal, New Daffodil Public School, Gali No. 5, Prem Colony, Bawana Road, Narela, Delhi-110040.

**Conditions for validity of fire safety certificate:-**

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional if fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing Department shall always be permitted and followed.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
8. The owner / occupier shall apply for renewal of this Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37) along with copy of the certificate, six months prior to its expiry.

**INSPECTION REPORT**

1.	Name & address of the building	New Daffodil Public School, located at Gali No. 5, Prem Colony, Bawana Road, Narela, Delhi-110040		
2.	Type of Occupancy	Educational Building (Group-B)		
3.	Building comprised of	Ground + 03 Upper Floors		
4.	Type of Case	New case		
5.	Details of previous NOC	Nil		
6.	Fire Safety directives letter No	Nil		
7.	Date of inspection	26/02/2026		
8.	Name of the Inspecting Officers	Aman Kumar Lathar, ADO (BW/RN)		
9.	Name and designation of officers from the building side	Sh. R.P. Tyagi (Owner)		
10.	Year of Construction	2025		
11.	Applicant's letter no.	Email dated 13/01/2026		
<b>S. No.</b>	<b>Minimum Standards on fire prevention and fire safety U/R 33</b>	<b>NBC Part-IV Requirement</b>	<b>Provided at site</b>	<b>Remarks MR/NMR</b>
1	<b>Access to building</b>			MR
	• Road width	6.0 m	Provided	MR
	• Gate width	4.5 m	Provided	MR
	• Width of internal road	NA	NA	NA
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases			MR
	• Upper Floors	02	Provided	MR
	• Basements	NA	NA	NA
	b. Width of staircases			MR
	• Upper Floors	1.50 m each	1.60 m & 1.80 to 2.05 m (Ramp)	MR
	• Basements	NA	NA	NA
	c. Protection of exits			NA
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	02	Provided	MR
	e. Width of Corridor	1.5 m	Provided	MR
	f. Door Size	1.20 m	Provided	MR
3	<b>Compartmentation.</b>			NA
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	<b>Smoke Management System.</b>			NA
	• Basements	NA	NA	NA
	• Upper floors	Required	Natural Ventilation	MR
5	<b>Fire Extinguishers</b>			
	• Total numbers	10 nos.	Provided	MR
	• Types	ABC/CO <sub>2</sub> type	Provided	MR
	• IS marking	Required	Provided	MR

R. A

6	<b>First-Aid Hose Reels.</b>			
	• Total numbers on each floor	01 no.	Provided	MR
	• Length of hose reel hose	30m	Provided	MR
	• Nozzle diameter	5mm	Provided	MR
7	<b>Automatic fire detection and alarming system.</b>			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8	<b>MOEFA</b>			
9	<b>Public Address System.</b>			
		NA	NA	NA
10	<b>Automatic Sprinkler System.</b>			
	• Basement at some location	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11	<b>Internal Hydrants</b>			
	• Size of riser/down-comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA
	• Hose Box	NA	NA	NA
12	<b>Yard Hydrants.</b>			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13	<b>Pumping Arrangements.</b>			
	• Ground Level			
	➤ Discharge of main Pump	NA	NA	NA
	➤ Head of Main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey Pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Starting/ Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	450 lpm	Provided	MR
	➤ Head of the pump	40 m	Provided	MR
	➤ Power Supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14	<b>Captive Water Storage for fire fighting.</b>			
	• Underground tank capacity	NA	NA	NA
	➤ Draw-off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	10,000 ltrs.	11,000 ltrs.	MR
15	<b>Exit Signage.</b>			
		Required	Provided	MR

*(Handwritten signature/initials)*

MR  
MR  
R

Provision of Lifts.			
16	<ul style="list-style-type: none"> <li>Pressurization of Lift Shaft</li> <li>Pressurization of Lift lobby</li> <li>Communication In lift Car</li> <li>Fireman's Grounding Switch</li> <li>Lift Signage</li> </ul>	NA	NA
		NA	NA
		NA	NA
		NA	NA
		NA	NA
		NA	NA
17	Standby power supply	Required	Provided
18	Refuge Area.	NA	NA
	➤ Total Area	NA	NA
	➤ Location	NA	NA
19	Fire Control Room	NA	NA
	• Detector System Panel	NA	NA
	• Flow Switch Panel	NA	NA
	• PA System Panel	NA	NA
	• Battery backup	NA	NA
	• Building Floor Plans	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any:		

The fire protection systems provided in the building were checked and found functional at the time of inspection.

Keeping in view of the substantial compliance of the minimum standards of fire prevention & fire safety measures as required under the rules and it is recommended to grant Fire Safety Certificate under rule 35 of Delhi Fire Service Rules 2010.

Accordingly, DFA is prepared & put up for approval please.

~~DO (W)~~ ~~ADP~~  
27/02/2026

~~ADP~~  
27/02/26  
Aman Kumar Lathar  
ADO (BW/RN)

By CFO (W)

ADP  
27/02/26

~~Pr. Director~~

By CFO to Secy.

By CFO (W)

27/02/26

F.T. please

ADO (BW)

F.T. letter is put-up for your signature pl

~~DO (W)~~

ADP  
06/03/26

ADP  
06/03/26

F.P. wing