



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

7/5  
आजादी का  
अमृत महोत्सव

No.F6/DFS/MS/School/SZ/2025/ 146

Dated: 11/03/2025

To

The Chairman,  
New Green Valley Public School,  
A-7, Om Nagar, School Road,  
Near Om Garden, Badarpur, New Delhi-44.

**Sub:-** Regarding issuance of Fire Safety Certificate in r/o New Green Valley Public School located at A-7, Om Nagar, School Road, Near Om Garden, Badarpur, New Delhi-44.

Sir,

With reference to the letter bearing outdoor diary no. 11588 dated 20.01.2025 on the subject cited above, it is informed that the school building was inspected by Assistant Divisional Officer (M. Road) from this department on 05.03.2025 in the presence of manager and it was observed that the building is comprised of Ground + 01 upper floors. During the inspection following shortcomings were observed:-

1. Alternate staircase of width 1.50 meters has not been provided.
2. Six nos. of fire extinguishers has not been provided.
3. First aid hose reels has not been provided.
4. Fire pump of 450 LPM with head 40 m has not been provided.
5. Overhand tank capacity of 10,000 liters for firefighting has not been provided.
6. Exit signage has not been provided.
7. Two nos. of staircases continuous to terrace has not been provided.

In view of above shortcomings, the application for issuance of Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the school management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(Atul Garg)  
Director

Delhi Fire Service

05/3

**Copy to:-**

1. The Dy. Director of Education, GNCT of New Delhi DISST. South Block-C, Defence Colony, New Delhi-24.