



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

75
आज़ादी का
अमृत महोत्सव

C-33

No. F6/DFS/MS/School/SZ/2025/ 137

Dated: 05/03/2025

To

The Principal,
M/s New Way Public School,
R-786/7, Fazal Chowk Abdul Hameed Road,
Joga Bai Extn., Jamai Nagar, Okhla, New Delhi-25.

Sub:- Regarding renewal of Fire Safety Certificate in respect of M/s New Way Public School located at R-786/7, Fazal Chowk Abdul Hameed Road, Joga Bai Extn., Jamai Nagar, Okhla, New Delhi-25.

Sir,

With reference to your email dated 23.01.2025 on the subject cited above, it is informed that the school building was inspected by officer concerned of this department on 27.02.2025 in the presence of Sh. Rizwan Ahmed (Owner) and following shortcoming was observed.

1. Hose reel found non functional.
2. Fire pump found non functional.
3. Overhand tank capacity of 10,000 liters for firefighting has not been provided.
4. Exit signages found removed.

In view of above shortcomings, the application for issuance of Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the school management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(Arul Garg)
Director

Delhi Fire Service

27/2/25 C

Copy to:-

1. The Dy. Director of Education, GNCT of New Delhi DISST. South Block-C, Defence Colony, New Delhi-24.