




GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001



No. F.6/DFS/MS/Hospital/2025/SZ/ 620

Dated: 16/12/2025

To

The Assistant Engineer (E) HSW 2,
PWD EMESD South West,
E-mail: pwdemd3531@gmail.com
Deen Dayal Upadhyay Hospital,
Hari Nagar, New Delhi-110064

Sub: Regarding issuance of Fire Safety Certificate in r/o Nurses Hostel Block at DDU Hospital,
Hari Nagar, New Delhi-110064


Sir,

This has reference to your letter F. No. 9(2)/AE(E)/HSW-2/PWDHMESD/DDUH/2025-26/136 dated 10/11/2025 received vide Diary No. 445/PD dated 12/11/2025. In this connection, it is to inform you that the said premise was inspected by the officer concerned of this department on 26/11/2025 in the presence of Sh. Subham & Ram Avtar (Fire Operators). During course of inspection, the shortcomings observed are as below.

1. One of the staircases found blocked & unusable and other staircase blocked at 7th floor.
2. Fire/Smoke check door found broken/defective at some places as indicated during inspection.
3. Sealing of electrical shaft not provided horizontally & vertically.
4. Hose-reel hose system at each floor found non-functional.
5. Manually operated electrical alarm system found partially functional.
6. Internal and yard hydrants found non-functional and hose-boxes empty.
7. Fire pumps were not on auto mode.
8. 3rd floor half portion, 8th & 9th Floor could not be checked being under lock and key.

In view of the above, renewal of fire safety certificate cannot be considered at this stage. You are requested to rectify/submit compliance of the above-mentioned shortcomings under intimation to this department for further action in the matter.

Yours faithfully,


(A.K. Malik)
Dy. Chief Fire Officer (SZ)
Delhi Fire Service

Copy to: -

1. The Medical Superintendent, DDU Hospital, Hari Nagar, New Delhi-110064.