



No. F6/DFS/MS/School/NDZ/2025/ 232

Dated: 17/04/2025

To,

The Principal,
Nigam Pratibha Vidyalaya
East Gokul Puri – II,
Delhi – 110094.

Subject: - Regarding grant of Fire Safety Certificate in r/o Nigam Pratibha Vidyalaya located at East Gokul Puri – II, Delhi – 110094.

Sir,

This has a reference to your Outdoor Diary No. 14529 dated 17/03/2025, on the subject cited above. In this connection, it is to inform you that premises was inspected by the officer concerned of this department on 05/03/2025 in the presence of Mr. Narendar Singh Kamal (Principal) and observed that building comprised of ground plus three upper floors.

Following shortcomings were observed during time of inspection:

1. Two staircase of width 1.10 meter & 1.20 meter are provided against requirements of 1.50 meters each.
2. All fire extinguishers found empty.
3. First-Aid-Hose Reel provided but not functional.
4. Terrace level fire pump capacity of 450 LPM provided but not functional.
5. Terrace fire water tank of 1,000 liters provided against requirement of 10,000 liters.
6. Exit & floors Signage's not provided at strategic location in the building.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(ATUL GARG)
DIRECTOR

o/c DELHI FIRE SERVICE

Copy to:-

1. The Director of Education, East Delhi Municipal Corporation, 419, Udyog Sadan, Patparganj Industrial Area, Delhi - 110092.