



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No. F6/DFS/MS/2025/School/ 351

Dated: 07/05/2025

To

The Principal
Nigam Pratibha Vidyalaya,
Mangal Bazar Road, B-Block,
Jahangir Puri, Delhi-110033.

Sub: - Regarding renewal of fire safety certificate in r/o Nigam Pratibha Vidyalaya (School ID No-1253006/1253180) located at B-Block, Mangal Bazar Road, Jahangir Puri, Delhi-110033.

Sir,

Please refer to your letter no. nil received in this department vide outdoor dairy no. 788 dated 21/04/2025 on the subject cited above. In this connection this is to inform you that the above mentioned site was visited by the officer concerned of this department on 26/04/2025 in the presence of Sh. Ravi Shankar (Incharge) and building was comprised of ground & first floor to verify the compliance of the shortcomings/ observations already communicated by this department vide letter of even no.F6/DFS/MS/2024/School/815 dated 11/12/2024 and observed that the shortcomings have not been removed so far, (Copy enclosed).

Keeping in view of above, grant of Fire Safety Certificate cannot be considered at this stage.

Yours faithfully

(Atul Garg)

Director

Ph:-011-23414000

etc Garg

Copy to:-

1. The Dy. Director, Education Department, Civil Line Zone, 16 Rajpura Road, Delhi.

5/5/2025

C19



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

No. F6/DFS/MS/2024/School/ 815

Dated: 11/12/2024

To

The Principal
Nigam Pratibha Vidyalaya B-II,
B-Block, Jahangir Puri, Delhi-110033.

Sub: - Regarding renewal of fire safety certificate in r/o Nigam Pratibha Vidyalaya B-II, (School ID No-1253006) located at B-Block, Mangal Bazar Road, Jahangir Puri, Delhi-110033.

Sir,

Please refer to your letter No- Nil dated 05.11.2024 received in this department vide outdoor dairy no.8599 dated: 05.11.2024 on the subject cited above. In this connection this is to inform you that the above mentioned site was visited by the officer concerned of this department on 04.12.2024 to check the existing fire safety measures. During inspection it has been observed that the school premise is comprised of ground & first floor each. At the time of inspection Mr. Ravi Shankar (Incharge) was also present at site. During the course of inspection the observations/ shortcomings made are as under:-

- 1 Electrical panel below in staircase needs to be removed/shifted in a safer place.

Keeping in view of above, renewal of Fire Safety Certificate cannot be considered at this stage & rejected. You are requested to rectify the above mentioned shortcomings under intimation to this department; till such time running of school building is at your own risk & responsibility.

Yours faithfully

(Atul Garg)
Director

Ph:-011-23414000

Copy to:-

1. The Dy. Director, Education Department, Civil Line Zone, 16 Rajpura Road, Delhi.

of c
16/12