



C-16



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001**

No.F.6/DFS/MS/School/2025/NDZ/ 279

Dated: 25/04/2025

To,
The Principal,
Nigam Pratibha School,
East Azad Nagar, Shahdara South Zone,
Delhi-110051

Subject:-Regarding renewal of Fire Certificate in r/o Nigam Pratibha School located at East Azad Nagar, Shahdara South Zone, Delhi-110051.

Sir,

This is in reference to your letter No. A/MCD/EAN/SH.S/2025/15 dated 03/04/2025 on the subject cited above. In this connection, it is to inform you that the officer concerned of this department has visited the school on 16/04/2025 in presence of Sh. Hemlata, Principal and observed that the shortcomings as communicated earlier vide letter No. F.6/DFS/MS/School/2015/1980 dated 28/08/2015 (copy enclosed) have not been complied yet.

In view of the above Fire Safety Certificate cannot be considered at this stage. You are requested to rectify the shortcomings communicated vide above mentioned letter under intimation to this office for further action.

Encl:- As above

Yours faithfully

(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

Copy to:-

The Director of Education (MCD)
15th Floor, E-Block, Dr. S.P. Mukahrjee Civic Center, JLN Marg, New Delhi-110002

C-15

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110001

No. *F6/DFs/ms/school/2015/1980*
To,

Dated: *28/08/15*

The Principal
EDMC Primary School,
East Aazad Nagar, Delhi-51

Sub: - Regarding issue of "Fire Safety Certificate" from fire safety point of view in r/o EDMC Primary School, East Aazad Nagar, Delhi-51

Madam,

Please refer to letter dated 01.08.2015 on the subject cited above. In this connection this is to inform you that officer concerned of this department inspected the school to verify the fire safety arrangements in accordance with the Delhi Fire Service Act, 2007 and Rules 2010. At the time of inspection Principal was present and it was observed that the school building is comprised of ground plus two upper floors and have following shortcomings:-

1. An additional staircase having width not less than 0.75 m is required.
2. First Aid Hose reels are not provided.
3. Fire pump having capacity 450 LPM out put at 40 m head not provided.
4. Over head water storage tank capacity 10,000 liters for firefighting not provided.
5. Exit signs not provided

In view of above, the fire safety certificate cannot be issued at this stage. Therefore you are requested to rectify the above said shortcoming under the intimation to this department for further course of action.

Yours faithfully



(Rajesh Panwar)

Dy. Chief Fire Officer

Ph. 011-23412025

6/8/15

Copy to:-

1. The Director of Education,
East Delhi Municipal Corporation,
419, Udyog Sadan, Patparganj Industrial Area, Delhi-92.
2. The Principal (2nd Shift)
EDMC Primary School, East Aazad Nagar, Delhi-51