



No. F6/DFS/MS/MOTEL/SZ/2026/ 269

Dated 3/02/2026

To,

The Commissioner,  
Municipal Corporation of Delhi,  
Civic Center, New Delhi – 110002.

Subject: - Regarding grant of Fire Safety Certificate in r/o M/s Motel **OODLES** (Karm Events and Management Private Limited) located at 759, 760, 761 & 762 Main Road, Chattarpur, New Delhi – 110074.

Sir,

This has a reference to MHA application No. 2026011400473 dated 14/01/2026, on the subject cited above. In this connection, it is to inform you that premises was inspected by the officer concerned of this department on 09/02/2026 in the presence of Mr. Puneet Sharma (D.M) and observed that building comprised of Basement & Ground floor (Basement is sealed by MCD).

Following shortcomings were observed during time of inspection:

1. Fire Check door found removed at some places.
2. Smoke managements system provided but not functional.
3. Fire line found damaged at some places and need to be repaired /replaced
4. First-Aid-Hose Reel provided but not functional.
5. Automatic Fire Detection and Alarm System provided but not functional.
6. Carbon Monoxide detector not provided in all guest rooms.
7. MOEFA found removed.
8. Public Address System provided but not functional.
9. Internal Hydrants and Yard Hydrants provided but not functional.
10. Hose Boxes found empty.
11. Fire pumping Arrangements provided but not functional.
12. Overhead tank capacity 10,000 liters found removed.
13. Exit Signage's not provided at strategic location in the building.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is **rejected**. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

  
A.K. Malik  
Dy. Chief Fire Officer  
Delhi Fire Service