

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI- 110001**

Nö. F.6/DFS/MS/2025/SZ/ 103
To

Dated: 11/03/2025

Sh. Ritesh Jain
Prop. No D-14, Pushpanjali,
Pitam Pura, Delhi

Sub: Regarding issuance of FSC in r/o M/s Bouncing Pouncing located at Ground floor of Okhla NSIC Metro Station of Line 8 (Janak Puri West to Kalindi Kunj Section) New Delhi

Sir,

This has reference to your letter received through Outdoor diary no 12905 dated 25/02/2025 on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 06/03/2025 in the presence of Mr. Ritesh Jain to verify the fire safety measures installed in the building. Accordingly fire safety arrangement were tested / checked and found following observation.

1. There are three exit doors available in the game zone. Out of there three, one door having width of 2 mtr is open & two doors found closed.
2. Exit signage's not provided at some places.
3. The eating house is running inside the gaming zone area, which may cause to a fire. The eating house needs to be segregated from the gaming zone area.
4. Inflammable material (Plastic & PVC Sheets for decorative material) is being used for wall paneling/ ceiling level, which is not acceptable as per clause 7.31 of UBBL-2016.

The same observations has already been issued and communicated earlier by this department vide letter of even no 30 dated 20/01/2025.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

Copy To-

1. The Joint Commissioner of Police, Lic/Branch, 1st Floor, P.S Defence Colony, New Delhi 110049