



75  
Azadi Ka  
Amrit Mahotsav

C-92

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE**  
**NEW DELHI-110001**

No. F6/DFS/MS/2026/WEST ZONE/ 1\

Dated 05/01/2026

To,

The Commissioner (MCD),  
SPM Civic Centre,  
JL Nehru Marg, Delhi-110002

Sub:- Special Drive for surprise inspection in r/o eating houses / restaurants in Delhi from Fire prevention & Fire Safety point of view.

Sir,

As per the office order No. F6/DFS/HQ/2025/2127 dated 10/12/2025, surprise inspection of eating house namely **ONYX (A unit of Shots Café) located at Plot No-3, Ground & First Floor, LSC Gujrawala Town Part-I, Delhi-110009** was conducted by officer of this department on dated 27/12/2025 in the presence of Sh. Sanjay Singhal to ascertain the availability & operability of the Fire prevention & Fire Safety measure provided in the building and following observation were made during the time of inspection.

1. Over Head tank found empty.
2. Starting pannel of Fire pump found damaged.
3. Fire Pump, MOEFA, Internal Hydrants & Hoe Reel Hoses provided but found nonfunctional.
4. Wiring of pannel disconnected from main of electric supply.


**The above-mentioned shortcomings should be complied latest by 14 days (i.e.10/01/2026).**

Keeping in view of above, Fire Safety Certificate issued by this department vide letter F6/DFS/MS/EH/2024/230 Dated 19/07/2024 to the **restaurant will remain suspended** until the compliance of the above mentioned shortcomings. The occupancy of the building / premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner / occupier.

Yours faithfully

  
05/01/26  
(S.K. Dua)

Dy. Chief Fire Officer (WZ)



Copy to:-

1. Sh. Sanjay Singhal, ONYX (A unit of Shots Café) located at Plot No-3, Ground & First Floor, LSC Gujrawala Town Part-I, Delhi-110009.