



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001**

No.F.6/DFS/MS/Bnqt./WZ/2025/204

Dated: 04/12/2025

To,

Sh. Manpreet Singh Grewal,
M/s Oreanns Banquet (A Unit of Ghar O Bar Hospitality Pvt. Ltd.)
Plot No. 69/6A, Najafgarh Road, Moti Nagar,
New Delhi-110015.

Subject:-Regarding renewal of Fire Safety Certificate in r/o M/s Oreanns Banquet (A Unit of Ghar O Bar Hospitality Pvt. Ltd.) at Plot No. 69/6A, Najafgarh Road, Moti Nagar, New Delhi-110015.

Sir,

This has reference to MCD application ID No. 2025110814672 dated 10/11/2025 on the subject cited above. In this connection, it is to inform you that the premises was visited by the officer concerned of this department on dated 21/11/2025 in presence of Sh. Dupinder Deep Gill. The premises is comprised of ground plus three upper floors. The following shortcomings were observed during the time of inspection.

1. Three temporary rooms constructed at terrace shall be removed.
2. The basement staircase width 02 meters & 1.05 meter are provided against the requirement of staircase width 02 meters & 1.50 meter.
3. Fire check doors shall be provided at the exit and in the basement as required.
4. First-Aid Hose reel nozzle found missing.
5. MOEFA provided but not functional.
6. Overhead tank capacity 20,000 liters is provided against the requirement of 30,000 liters capacity.

In view of above shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire Safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,


03/12/25
(S. K. DUA)

**DY. CHIEF FIRE OFFICER
DELHI FIRE SERVICE**

Copy to:-

The Commissioner, MCD, Civic Centre, New Delhi
MCD ID No. 2025110814672

o/c R.