



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001



No F6/DFS/MS/2026/Hospital/ 220

Dated: 29/09/2026

FIRE SAFETY CERTIFICATE

Certified that the M/s Pacific One health Hospital (A unit of Pacific World Foundation) situated at Plot No.29, Block-62, New Rohtak Road, Karol Bagh, New Delhi-110005, comprised of B + B (Mezz.) + Stilt + Ground + 03 upper floors was inspected by the officer concerned of this department on **03.09.2026** in the presence of Mr. Ajay Kapoor (Architect) and found that the said premises have complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premise is fit for occupancy "Institutional building" with effect from 29/09/2026 for a period of 03 (Three) years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 29/09/2026 at New Delhi by


(Dr. S. K. Tomar)
Chief Fire Officer
Delhi Fire Service

Copy to:

1. The Authorized Signatory, M/s Pacific Onehealth Hospital (A unit of Pacific World Foundation) situated at Plot No.29, Block-62, New Rohtak Road, Karol Bagh, New Delhi-110005.
2. The Commissioner, MCD, Civic Center, New Delhi: to kindly ensure the occupancy as detailed above and deviation in construction if any.
3. The Directorate General of Health Service, F-17, Karkardooma, Delhi-110032

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non-functional fire safety measure shall be at the responsibility of the management/occupier.
3. The trained fire-fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on
8. All the means of escape shall be kept free of any obstruction all the time to evacuate the occupant, in a safe manner, in the event of emergency.

http://www.delhi.gov.in/wps/wcm/connect/doi_t_fire/FIRE/Home/Fire+Safety+Acts+and+Rules
/ http://www.delhi.gov.in/wps/wcm/connect/doi_t_fire/FIRE/Home/Forms

INSPECTION REPORT

1. Name & address of the building	M/s Pacific Onehealth Hospital (A unit of Pacific World Foundation) situated at Plot No.29, Block-62, New Rohtak Road, Karol Bagh, New Delhi-110005.			
2. Type of Occupancy	Institutional (Hospital)			
3. Comprised of building	Basement (lab) + basement mezz (office) + stilt (Parking) + Ground (OPD/Pharmacy) + First (consult Room) + Second (Ward & Patient Room) + Third (OT, HDU, CSSD, ICU, etc.)			
4. Type of Case	New Case			
5. Details of Previous NOC	NA			
6. Fire Safety directives letter No	F.6/DFS/MS/BP/2026/163 dated 27.05.2026.			
7. Date of inspection	03.09.2026			
8. Name of Inspecting Officer	ADO(KB) & DO(CD)			
9. Name and designation of officers From the building side	Mr. Ajay Kapoor (Architect)			
10. Year of Construction	2026			
11. Applicant's letter No.	OD No.4954 dated 11.08.2026			
S. No	Minimum Standards on fire prevention and fire safety U/R 33	BBL/NBC Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	• Road width	09m	30m	MR
	• Gate width	4.5m	Provided Directly accessible	MR
	• Width of internal road	-NA-	-NA-	-NA-
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	02nos.	02nos.	MR
	• Basements	02nos.	02nos.	MR
	b. Width of staircases			
	• Upper Floor	2m	2m	MR
	• Basements	2m	2m	MR
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	Required	Provided	MR
	d. No. of continuous staircases to terrace	Required	Provided	MR
	e. Width of Corridor	2.4m	Provided	MR
	f. Door Size	1.25m to 2m	Provided	MR
3.	Compartmentation			
	a) Fire check door	Required	Provided	MR-
	b) Sealing of electrical shafts	Required	Provided	MR
	c) Fire Rating of shaft door	-NA-	-NA-	-NA-
	d) Water Curtain	-NA-	-NA-	-NA-
	e) Fire Dampers	-NA-	-NA-	-NA-
4.	Smoke Management System			
	a) Basements	Mechanical/ Natural	Provided	MR
	b) Upper floors	Mechanical/ Natural	Provided	MR
5.	Fire Extinguishers			
	a) Total numbers	20nos.	Provided	MR
	b) Types	ABC/CO2	ABC/CO2	MR
	c) IS marking	ISI marked	Yes	MR
6.	First-Aid Hose Reels			
	a) Total numbers on each floor	02nos.	Provided	MR
	b) Length of hose reel hose	30mm	Provided	MR

	c) Nozzle diameter	5m	Provided	MR
7.	Automatic fire detection and alarming system			
	a) Type of detectors	Smoke/Heat	Provided	MR
	b) Location of Main Panel	Gr. floor	Provided	MR
	c) Location of Repeater Panel	Required	Provided	MR
	d) Alternate source of power	Required	Provided	MR
	e) Hooters' Location	On all floors	Provided	MR
8.	MOEFA with talk back & PA System	Required	Provided	MR
9.	Public Address System	-NA-	-NA-	-NA-
10.	Automatic Sprinkler System			
	a) Basement	Required	Provided	MR
	b) Ground & Upper Floors	Required	Provided	MR
	c) Sprinkler above false ceiling	-NA-	-NA-	-NA-
11.	Internal Hydrants			
	a) Size of riser/down-comer	Required	Provided	MR
	b) Number of hydrants per floor	Required	Provided	MR
	c) Hose Box	Required	Provided	MR
12.	Yard Hydrants			
	a) Total number of hydrants	-NA-	Provided	-NA-
	b) Hose Box	-NA-	Provided	-NA-
13.	Pumping Arrangements			
	• Ground Level			
	➤ Discharge of main Pump	1620lpm	1620lpm	MR
	➤ Head of Main pump	60m	Provided	MR
	➤ Number of main pumps	01nos.	01nos.	MR
	➤ Jockey Pump out put	180lpm	180lpm	MR
	➤ Jockey pump head	60m	Provided	MR
	➤ Standby Pump out put	1620lpm	1620lpm	MR
	➤ Standby Pump Head	60m	Provided	MR
	➤ Auto Starting/Manual Stopping	Required	Provided	MR
	➤ Pump House Access	Required	Provided	MR
	Terrace level			
	➤ Discharge of pump	-NA-	900 lpm	-NA-
	➤ Head of the pump	-NA-	36 m	-NA-
	➤ Power Supply	-NA-	Provided	-NA-
	➤ Auto Starting of pump	-NA-	Provided	-NA-
14.	Captive Water Storage for fire fighting			
	• Underground tank capacity	75 KL	Provided	MR
	➤ Draw-off connection	Required	Provided	MR
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	Required	Provided	MR
	• Overhead Tank capacity	10,000ltr	Provided	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	a) Pressurization of Lift Shaft	Required	Provided	MR
	b) Pressurization of Lift lobby	Required	Provided	MR
	c) Communication In lift Car	Required	Provided	MR
	d) Fireman's Grounding Switch	Required	Provided	MR
	e) Lift Signage	Required	Provided	MR
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area.			

	a) Total Area	-NA-	-NA-	-NA-
	b) Location	-NA-	-NA-	-NA-
19.	Fire Control Room			
	a) Detector System Panel	-NA-	-NA-	-NA-
	b) Flow Switch Panel	-NA-	-NA-	-NA-
	c) PA System Panel	-NA-	-NA-	-NA-
	d) Battery backup	-NA-	-NA-	-NA-
	e) Building Floor Plans	-NA-	-NA-	-NA-
20.	Special Fire Protection System for Protection of special Risks, if any:			
		-NA-	-NA-	-NA-

Accordingly, the fire protection systems provided in the building were tested/ checked randomly and found in working condition at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is **recommended to grant Fire Safety Certificate** under rule 35 of the Rule 27 of the Delhi Fire Service (Amendment) Rules, 2025.

Signature of the Inspecting Officer
Name: - Mukesh Verma
Designation:- DO/CD

Signature of the Inspecting Officer
Name: - Ajay Kumar Sharma
Designation:- ADO/KB

CFO (CD)

K. Verma
21/9/26

Rec:- 21/9/26

Principal Director

When did we receive
the application? None
25/8

CFO (CD)

K. Verma
25/9/26

DO (CD) Sir, the application is received on 11/8/26
vide out 2026 diary 4954 placed at C-80.
submitted please.

CFO (CD)

K. Verma
25/9/26

Principal Director

OK CFO may return.

None
25/9

CFO (CD)

K. Verma
25/9/26

DO (CD)