

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

No. F-6/DFS/MS/2025/WZ/0207/118

Dated 03/07/2025

To

The Manager,  
M/s Paradise Banquet ( A Unit of Raja Tents),  
Kh. No. 334, 100 ft. Road, Ghitorni  
Delhi.

Sub: - Regarding issuance of fire safety certificate in r/o M/s Paradise Banquet ( A Unit of Raja Tents),  
Kh. No. 334, 100 ft. Road, Ghitorni Delhi.

Sir,

This has reference to your Online Id no. 2025060609713 dated 06/06/25 & 2025052308947 dated 02.06.2025, on the subject cited above. In this connection it is to inform that the site was visited by the officer concerned of this department on 21/06/25 in the presence of Mr. Pawan,( care taker) and the following shortcomings were observed:

1. Compartmentation is not done as per NBC Part- 4.
2. FCD is not provided at staircases & lift serving to basement.
3. Smoke management system is not provided in basement and upper floor.
4. 01 nos of Hose reel& hydrant is provided against the requirements of 02 nos at each floor.
5. Overhead tank is provided of 8000 liters against the requirement of 25,000 ltr.
6. MOEFA is not provided.
7. Terrace of pump of 450 LPM is provided against the requirements of 900 LPM & 450 LPM.
8. Lift signage's, fire man switch and exit signage's are not provided.
9. Building plan as uploaded on the portal does not match with existing profile of site and also not legible to ascertain the height of building.

In view of above, the case is rejected and FSC cannot be issued at this stage. Further, the occupancy of building /premises in absence requisite fire & life safety arrangements shall be at the risk and liability of the owner/occupier. The statutory/licensing authority may take suitable action as deemed fit.

Yours faithfully

(Atul Garg)  
DIRECTOR

Delhi Fire Service

Copy to :

1. The Addl. Commissioner of Police (Lic), First Floor, P.S. Defence Colony New Delhi. Online Id no. 2025060609713 dated 06/06/25 & 2025052308947 dated 02.06.2025.