



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110 001



Dated: 12/02/2026

No. F.6/DFS/MS/WZ/GH/2026/127

To,
Mr. Bishan Dutt Pathak,
House No.C-53, Sigma-2, Gautam budh Nagar,
Greater Noida,
Utter Pradesh-20308.

Sub: Renewal of FSC in r/o M/s The Paradise Hotel and Banquet located at B-97, GF, FF, Wazirpur Industrial Area, Delhi-110052.

Sir,
This is refer to online application no. 2026011200388 dated 12.01.2026, received in this department on the subject cited above. The premise was inspected by the concern nominated authority of this department on 02.02.2026, in presence of Mr. Bishan Dutt Pathak to ascertain the availability and operability of the fire prevention and fire safety measures. Your request for renewal of FSC is rejected under sub rule (3) of Rule 37 of DFS Rules-2010 due to following reason:

1. FCD found removed at some places.
2. Smoke management system found removed.
3. Nozzles in hose reel and hose in hose box found missing.
4. MOEFA and smoke detection system is not functional.
5. Pumps are not kept in auto mode due to some maintenance work in system.
6. Banquet was also found running on 3rd floor, whereas CAF mentioned ground and first floor only.

In this regard as stipulated in sub Rule 37 of DFS Rules, 2010 you may apply with a fresh application for renewal of fire safety certificate under sub-rule (2) on Form "J" /MCD Portal with compliance of above shortcomings. The web links for DFS Act-2007/ Rules 2010 & Form "J" are as under:

http://www.delhi.gov.in/wps/wcm/connect/doi_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/
http://www.delhi.gov.in/wps/wcm/connect/doi_fire/FIRE/Home/Forms

Yours faithfully


11/02/26

(S. K. Dua)
Dy. Chief Fire Officer (WZ)
Delhi Fire Service



Copy To:-

1. MCD Portal Id- 2026011200388 dated 12.01.2026.