

No. F6/DFS/MS/School/NDZ/2025/ 1012

Dated: 18/08/2025

FIRE SAFETY CERTIFICATE

Certified that the **Piccolo School** located at **D - Block, Preet Vihar, New Delhi - 110092**, comprised of Basement, Ground plus one upper floor (School at Ground plus one upper floor), owned / occupied by **Piccolo School** was issued FSC vide letter No. F6/DFS/MS/School/2016/NDZ/1228 dated 03/08/2016. The school building has complied with the fire prevention and fire safety requirements in accordance with the Circular No.F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01/03/2011 issued by the Director of Education and re-inspected by the officers concerned of this department on 30/07/2025 in presence of Mr. Ayush & Ms. Gurpreet Kaur (Principal) of the school and that the school building is fit for occupancy class **(Group - B) "Educational Building"** for Ground plus one upper floor only with effect from 18/08/2025 for a period of **three years** in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rule 2010 & also conditions printed bellow.

Issued on 18/08/2025 at New Delhi by.

[Signature]
18/08/2025

VIRENDRA SINGH
CHIEF FIRE OFFICER
DELHI FIRE SERVICE
@

Copy to: -

1. The Dy. Director of Education, D - Block, Anand Vihar, Delhi - 110092.
2. The Principal, Piccolo School, D - Block, Preet Vihar, New Delhi - 110092.

Conditions for the validity of Fire Safety Certificate

1. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry
2. All the means of escape shall be kept free of all the type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipment's and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the firefighting equipment's shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
5. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc. may be got verified from the authorities concerned.
6. This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT


01.	Name & address of the building	Piccolo School located at D-Block, Preet Vihar, New Delhi-110092.		
02.	Building is comprised of	Basement + Ground + 01 upper floor (School at Ground + 01 upper floor)		
03.	Type of occupancy	Educational Building		
04.	Type of case	Renewal		
05.	Details of previous FSC	F6/DFS/MS/School/2016/NDZ/1228 dated 03/08/2016 (previously known as Blessings World International School)		
06.	Fire safety directives letter no.	F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01/03/2011		
07.	Date of inspection	30.07.2025.		
08.	Name of the inspecting officers	Yashwant Singh Meena, A.D.O / (L.N) & Ashok Kumar Jaiswal, D.O / (ED)		
09.	Name of the designation of officer from the building side	Mr. Ayush & Ms. Gurpreet (Principal)		
10.	Year of construction	2011		
11.	Applicant's letter no.	Outdoor dairy no. 3798 dated 16/07/2025		
S.No	Minimum standard of fire prevention and fire safety U/R 33	Circular Requirement	Provided at site	Remarks MR/NMR
01.	Access to Building:			
	A Road width	6.0 mtrs.	06 mtrs.	MR
	B Gate width	N/A	N/A	N/A
	C Width of internal road	N/A	N/A	N/A
02.	Number, Width, Type and Arrangement of Exits:			
	A Number of staircases			
	a Upper floor	01 no.	01 no.	MR
	C Basement	01 no.	01 no.	MR
	B Width of staircases			
	a Upper floor	1.50 mtrs.	1.50 mtrs.	MR
	C Basement	1.50 mtrs.	1.50 mtrs.	MR
	C Protection of exits			
	a Fire check door	N/A	N/A	N/A
	b Pressurization	N/A	N/A	N/A
	D No. of continuous staircases to terrace	N/A	N/A	N/A
	E Width of corridor	1.50 mtrs.	1.50 mtrs. ✓	MR
	F Door size	1.0 mtrs.	1.0 mtrs. ✓	MR
03.	Compartmentation:			
	A Fire check door	N/A	N/A	N/A
	B Sealing of electrical shafts	N/A	N/A	N/A
	C Fire rating of shaft door	N/A	N/A	N/A
	D Water curtain	N/A	N/A	N/A
	E Fire dampers	N/A	N/A	N/A
04.	Smoke Management System:			
	A Basement	N/A	N/A	N/A
	B Upper floor	N/A	N/A	N/A


05.	Fire Extinguisher:				
	A	Total numbers	06 nos.	08 nos.	MR
	B	Types	ABC/CO ₂	ABC/CO ₂	MR
	C	ISI marking	ISI Marked	ISI Marked	MR
06.	First-Aid-Hose Reel:				
	A	Total numbers of each floor	N/A	01 no. provided	N/A
	B	Length of hose reel hose	N/A	01 no. provided	N/A
	C	Nozzle diameter	N/A	01 no. provided	N/A
07.	Automatic Fire Detection and Alarming System:				
	A	Type of detectors	N/A	N/A	N/A
	B	Location of main panel	N/A	N/A	N/A
	C	Location of repeater panel	N/A	N/A	N/A
	D	Alternate source of power	N/A	N/A	N/A
	E	Hooters	N/A	N/A	N/A
08.	MOEFA:		N/A	N/A	N/A
09	Public Address System:		N/A	N/A	N/A
10.	Automatic Sprinkler System:				
	A	Basement	Required	Provided	MR
	B	Upper floor	N/A	N/A	N/A
	C	Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants:				
	A	Size of riser/down-comer	N/A	N/A	N/A
	B	Number of hydrants per floor	N/A	N/A	N/A
	C	Hose box	N/A	N/A	N/A
12.	Yard Hydrants:				
	A	Total number of hydrants	N/A	N/A	N/A
	B	Hose box	N/A	N/A	N/A
13.	Pumping Arrangements:				
1	Ground level				
	A	Discharge of main pump	N/A	N/A	N/A
	B	Head of main pump	N/A	N/A	N/A
	C	Number of main pumps	N/A	N/A	N/A
	D	Jockey pump out put	N/A	N/A	N/A
	E	Jockey pump head	N/A	N/A	N/A
	F	Standby pump out put	N/A	N/A	N/A
	G	Standby pump head	N/A	N/A	N/A
	H	Auto starting /manual stopping	N/A	N/A	N/A
	I	Pump house access	N/A	N/A	N/A
2	Terrace Level				
	A	Discharge of pump	N/A	450 LPM	N/A
	B	Head of the pump	N/A	40 m	N/A
	C	Power supply	N/A	Provided	N/A
	D	Auto starting of pump	N/A	Manual	N/A

14. Captive Water Storage for Fire Fighting:				
A	Underground tank capacity	N/A	N/A	N/A
B	Draw-off connection	N/A	N/A	N/A
C	Fire service inlet	N/A	N/A	N/A
D	Access to tank	N/A	N/A	N/A
E	Overhead tank capacity	5,000 liters.	10,000 liters.	MR
15. Exit Signage:		Required	Provided	MR
16. Provision of Lifts:				
A	Pressurization of lift shaft	N/A	N/A	N/A
B	Pressurization of lift lobby	N/A	N/A	N/A
C	Communication in lift car	N/A	N/A	N/A
D	Firemen's grounding switch	N/A	N/A	N/A
E	Lift signage	N/A	N/A	N/A
17. Standby Power Supply:		NA	N/A	N/A
18. Refuge Area:				
A	Total area	N/A	N/A	N/A
B	Location	N/A	N/A	N/A
19. Fire Control Room:				
A	Detector system panel	N/A	N/A	N/A
B	Flow switch panel	N/A	N/A	N/A
C	PA system panel	N/A	N/A	N/A
D	Battery backup	N/A	N/A	N/A
E	Building floor plans	N/A	N/A	N/A
20. Special Fire Protection systems for protection of special Risks, if any:		NA	N/A	N/A


The fire protection system was randomly checked and tested and was found functional at the time of inspection.


Keeping in view of the deemed compliance of minimum standards on fire prevention and fire safety measures as required under the Rules the Fire Safety Certificate issued vide letter no. F6/DFS/MS/School/2016/NDZ/1228 dated 03/08/2016 under the Circular no F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01/03/2011 **is recommended to be renewed.**


 31/7/2025
 Signature of the Inspecting Officer
 Name : Yashwant Singh Meena
 Designation: ADO /Laxmi Nagar


 31.7.2025
 Signature of the Inspecting Officer
 Name : Ashok Kumar Jaiswal
 Designation: Divisional Office/ East



Dy. CFO / NDZ


 01/08/25

C.F.O.

 21/01/2025

Principal Director

Cfo to Gen.

DO (SD) 
 18/8/25

 11/08/25
 ADO/NDZ
 05/08/25