

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE**  
**NEW DELHI- 110001**

No. F.6/DFS/MS/School/2025/SZ/ 285

Dated: 25./04./2025

To

The Principal,  
M/s Pitamber Public School,  
74/1 Kishangarh, Vasant Kunj,  
New Delhi 110070

Sub: Regarding issuance of FSC in r/o M/s Pitamber Public School, at 74/1 Kishangarh, Vasant Kunj, New Delhi 110070

Sir,

This has reference to your letter no nil dated 17/03/2025 received through outdoor diary no 14564 dated 17/03/2025 on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 21.04.2025 in the presence of Ms. Ritu (Principal) observed that as per the record available in this department, NOC of the said school was granted vide letter no F6/DFS/MS/2006/1839 dated 31/07/2006 for Ground plus one upper floor only whereas the owner of school has now added two more floors and the building is now comprised of Ground and three upper floors. During the course of visit following observations were noticed:-

1. The access road to the premise is less than of 6m; hence the said school is not accessible to Fire tender/fire engine.
2. There are two staircases having width of 1.50 mtr & 1.30 mtr against the requirement of two staircase having width of 1.50 mtr each.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier.

Yours faithfully,

(ATUL GARG)  
DIRECTOR  
DELHI FIRE SERVICE

Copy to:-

1. The Directorate of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-54.