



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001




No. F6/DFS/MS/2026/WZ/Restaurant/164

Dated: 23/02/2026

FIRE SAFETY CERTIFICATE

Certified that the M/s Pizza Express (A unit of Bharti Overseas Pvt. Ltd.) located at Shop No.FO 03, 4th floor Unity One, Elegante NSP MRTS Station, OPP Wazirpur, District Centre, Pitampura, Delhi-110034, comprised of 02 tier basement + ground + 04 upper floors and Pizza Express restaurant is running at Shop No.FO 03, 4th floor in a Mall was inspected by the officers concerned of this department on 16.02.2026 in the presence of Mr. Naresh, and found that the said premises have complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules,2010 and that the premise is fit for occupancy class Assembly for Restaurant running at Shop No.FO 03, 4th floor only with effect from 23/02/2026 for a period of 03 (Three) years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 23/02/2026 at New Delhi by


23/02/26
(S. K. Dua)

Dy. Chief Fire Officer (WZ)
Delhi Fire Service

Copy to: -

1. The Commissioner, MCD, Civic centre, New Delhi: to kindly ensure the occupancy as detailed above and deviation in construction if any: MCD Portal Id-2026012100747 dated 27.01.2026.
2. The Manager, M/s Pizza Express (A unit of Bharti Overseas Pvt. Ltd.) located at Shop No.FO 03, 4th floor Unity One, Elegante NSP MRTS Station, OPP Wazirpur, District Centre, Pitampura, Delhi-110034.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on .
8. All the means of escape shall be kept free of any obstruction all the time to evacuate the occupant, in a safe manner, in the event of emergency.

http://www.delhi.gov.in/wps/wcm/connect/doiit_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/http://www.delhi.gov.in/wps/wcm/connect/doiit_fire/FIRE/Home/Forms

INSPECTION REPORT				
1. Name & address of the building	M/s M/s Pizza Express (A unit of Bharti Overseas Pvt. Ltd.) located at Shop No.FO 03, 4 th floor Unity One, Elegante NSP MRTS Station, OPP Wazirpur, District Centre, Pitampura, Delhi-110034.			
2. Type of Occupancy	Assembly			
3. Comprised of building	02 tier basement + ground + 04 upper floors			
4. Type of Case	New Case (Pizza Express restaurant is running at Shop No.FO 03, 4 th floor in a Mall)			
5. Details of Previous NOC	N/A			
6. Fire Safety directives letter No	N/A			
7. Date of inspection	16.02.2026			
8. Name of Inspecting Officer	Sh. Ajay Kumar Sharma ADO (Wazirpur/MN)			
9. Name and designation of officers From the building side	Mr. Naresh			
10. Year of Construction	2025 on MCD Portal			
11. Applicant's letter No.	Online application No.2026012100747 dated 27.01.2026.			
Unity One Elegante Mall issued FSC vide letter No.F.6/DFS/MS//Mixed/2025/SZ/318 dated 11.06.2025.				
S. No	Minimum Standards on fire prevention and fire safety U/R 33	NBC/UBBL Requirement	Provided at site	Remarks MR/NMR
1.	Access to building	Common with the Mall		
	• Road width	12m	16m	MR
	• Gate width	06m	Provided	MR
	• Width of internal road	06m	Provided	MR
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	02nos.	Provided by mall	MR
	• Basements	-NA-	-NA-	-NA-
	b. Width of staircases			
	• Upper Floor	1.5 m	Provided by mall	MR
	• Basements	-NA-	-NA-	-NA-
	c. Protection of exits			
	• Fire check door	Required in kitchen	Provided	MR
	• Pressurization	Restaurant within Mall	As Above	MR
	d. No. of continuous staircases to terrace	Required	Provided	MR
	e. Width of Corridor	Restaurant within Mall	As Above	MR
	f. Door Size	2 x 1.5m	Front total open	MR
3.	Compartmentation			
	a) Fire check door	Required in kitchen	Provided	MR
	b) Sealing of electrical shafts	Restaurant within Mall	As Above	MR
	c) Fire Rating of shaft door	Restaurant within Mall	As Above	MR
	d) Water Curtain	Restaurant within Mall	As Above	MR
	e) Fire Dampers	Restaurant within Mall	As Above	MR
4.	Smoke Management System	Common with the Mall		
	a) Basements	-NA-	-NA-	-NA-
	b) Upper floors	Mechanical/Natural ventilation	Provided	MR
5.	Fire Extinguishers			
	a) Total numbers	04nos.	Provided	MR
	b) Types	ABC/CO2	ABC/CO2	MR
	c) IS marking	ISI marked	Yes	MR
6.	First-Aid Hose Reels	Common with the Mall		
	a) Total numbers on each floor	Near to restaurant	Provided by mall	MR
	b) Length of hose reel hose	30mm	Provided by mall	MR

N/28 22


	c) Nozzle diameter	5m	Provided by mall	MR
7.	Automatic fire detection and alarming system Common with the Mall			
	a) Type of detectors	Smoke/Heat	Provided	MR
	b) Location of Main Panel	Restaurant within Mall	Provided by mall	MR
	c) Location of Repeater Panel	Restaurant within Mall	Provided by mall	MR
	d) Alternate source of power	Restaurant within Mall	Provided by mall	MR
	e) Hooters' Location	Restaurant within Mall	Provided by mall	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Restaurant within Mall	Provided by mall	MR
10.	Automatic Sprinkler System Common with the Mall			
	a) Basement	-NA-	As Above	-NA-
	b) Ground & Upper Floors	Required	Provided	MR
	c) Sprinkler above false ceiling	Required	Provided	MR
11.	Internal Hydrants Common with the Mall			
	a) Size of riser/down-comer	Restaurant within Mall	Provided by mall	MR
	b) Number of hydrants per floor	Restaurant within Mall	Provided by mall	MR
	c) Hose Box	Restaurant within Mall	Provided by mall	MR
12.	Yard Hydrants Common with the Mall			
	a) Total number of hydrants	Restaurant within Mall	Provided by mall	MR
	b) Hose Box	Restaurant within Mall	Provided by mall	MR
13.	Pumping Arrangements Common with the Mall			
	<ul style="list-style-type: none"> • Ground Level ➤ Discharge of main Pump ➤ Head of Main pump ➤ Number of main pumps ➤ Jockey Pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Starting/Manual Stopping ➤ Pump House Access 	Restaurant within Mall	Hyd=2850lpm Sprk=2850lpm	MR
		Restaurant within Mall	90m	MR
		Restaurant within Mall	02nos.	MR
		Restaurant within Mall	180lpm	MR
		Restaurant within Mall	90m	MR
		Restaurant within Mall	2850lpm	MR
		Restaurant within Mall	90m	MR
		Provided by mall	Provided	MR
		Provided by mall	Provided	MR
		Terrace level	Common with the Mall	
	➤ Discharge of pump	-NA-	As Above	-NA-
	➤ Head of the pump	-NA-	As Above	-NA-
	➤ Power Supply	-NA-	As Above	-NA-
	➤ Auto Starting of pump	-NA-	As Above	-NA-
14.	Captive Water Storage for firefighting Common with the Mall			
	• Underground tank capacity	Restaurant within Mall	Provided by mall	MR
	➤ Draw-off connection	Restaurant within Mall	Provided by mall	MR
	➤ Fire service inlet	Restaurant within Mall	Provided by mall	MR
	➤ Access to tank	Restaurant within Mall	Provided by mall	MR
	• Overhead Tank capacity	20,000ltr	Provided by mall	MR

QW


	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.	Common with the Mall		
	a) Pressurization of Lift Shaft	Restaurant within Mall	Provided by mall	MR
	b) Pressurization of Lift lobby	Restaurant within Mall	Provided by mall	MR
	c) Communication In lift Car	Restaurant within Mall	Provided by mall	MR
	d) Fireman's Grounding Switch	Restaurant within Mall	Provided by mall	MR
	e) Lift Signage	Restaurant within Mall	Provided by mall	MR
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area.			
	a) Total Area	-NA-	-NA-	-NA-
	b) Location	-NA-	-NA-	-NA-
19.	Fire Control Room	Common with the Mall		
	a) Detector System Panel	Restaurant within Mall	Provided by mall	MR
	b) Flow Switch Panel	Restaurant within Mall	Provided by mall	MR
	c) PA System Panel	Restaurant within Mall	Provided by mall	MR
	d) Battery backup	Restaurant within Mall	Provided by mall	MR
	e) Building Floor Plans	Restaurant within Mall	Provided by mall	MR
20.	Special Fire Protection System for Protection of special Risks, if any:	Restaurant within Mall	Provided by mall	MR

Accordingly, the fire protection systems provided in the building were tested/ checked randomly and found in working condition at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is **recommended to grant Fire Safety Certificate** under rule 35 of the Delhi Fire Service Rule 2010.



 Signature of the Inspecting Officer
 Name **Ajay Kumar Sharma**
 Designation **ADO(Wazirpur/MN)**

DO (West) 


 Pr. Director


 17/02/26

By. Cfo to Gen.



By. Cfo (WZ)



18/02/26
 F.T. please.


 ADO (WZ)


 19/02/26

FT letter is put up for kind
 perusal and signature please.


 20/02/26


 20/02/26