



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001



No: F.6/DFS/MS/EH/2026/SZ/ 146

Dated: 18 / 02 / 2026

To,

The Commissioner,
Municipal Corporation of Delhi,
9th Floor, Dr. SPM Civic Centre,
Minto Road, New Delhi-110002

Sub: **Regarding issuance of Fire Safety Certificate in r/o M/s Pizza Hut (A Unit of Devyani International Ltd) located at Shop No. 1, Plot No. 113, Block C-1, Janakpuri, New Delhi-110058**

Sir,

Please refer to online portal application No. 2026020301199 dated 03/02/2026. In this connection, it is to inform you that the said premise was visited by the officer concerned of this department on 10/02/2026 in the presence of Mr. Satish Rana (Manager) to verify the compliance of shortcoming issued by this office vide letter No. F.6/DFS/MS/EH/2026/SZ/101 dated 03/02/2026 and observed that the shortcomings are not yet complied.

In view of the above, issuance of fire safety certificate cannot be considered at this stage & rejected. The occupancy of the building till the compliance of the shortcomings shall be at the risk and liability of the owner/occupier/management.

Yours faithfully,

(M.K. Chattopadhyay)
Dy. Chief Fire Officer (FPW)
Delhi Fire Service

Copy to: -

1. Shri Abhishek Mittal, M/s Pizza Hut (A Unit of Devyani International Ltd), Shop No. 1, Plot No. 113, Block C-1, Ground Floor, Janakpuri, New Delhi-110058



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001



No. F.6/DFS/MS/EH/2026/SZ/ 101

Dated: 03/02/2026

To

The Commissioner,
Municipal Cooperation of Delhi,
9th Floor, Dr. SPM Civic Centre,
Minto Road, New Delhi-110002

Sub: Regarding issuance of Fire Safety Certificate in r/o M/s Pizza Hut (A Unit of Devyani International Ltd) at Shop No. 1, Plot No. 113, Block C-1, Ground Floor, Janakpuri, New Delhi-110058


Sir,

Please refer to online portal (etl.mcdonline.nic.in) application No. 2026010900320 dated 09/01/2026. In this connection, it is to inform you that the site was visited by the officer concerned of this department on 22/01/2026 in the presence of Mr. Satish (Manager). During the inspection, the shortcomings observed are as below.

1. First-aid hose-reel found provided but non-functional.
2. Terrace level fire pump found non-functional.
3. Overhead water storage for fire-fighting found empty.

In view of the above, application for issuance of fire safety certificate cannot be considered at this stage & rejected. The occupancy of the premise in the absence of requisite fire & life safety arrangements shall be at the risk and liability of the owner/occupier/management.

Yours faithfully,


(A.K. Malik)
Dy. Chief Fire Officer (SZ)
Delhi Fire Service

Copy to: -

1. Sh. Abhishek Mittal, M/s Pizza Hut (A Unit of Devyani International Ltd) at Shop No. 1, Plot No. 113, Block C-1, Ground Floor, Janakpuri, New Delhi-110058