



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110 001**



No. F.6/DFS/MS/WZ/EH/2026/131

Dated: 12/02/2026

To,

Mr. Parveen Kumar,  
House No.709, Sector-23, Sonipat,  
Haryana-131001.

**Sub:** Renewal of FSC in r/o M/s Play, Shop No. TF 01, Plot No. 7 & 8, City Square Mall, Shivaji Place, District Centre, Raja Garden, Delhi-110027.

Sir,


This is refer to online application no. 2026011300446 dated 13.01.2026, received in this department on the subject cited above. The premise was inspected by the concern nominated authority of this department on 03.06.2026, in presence of Mr. Dheeraj to ascertain the availability and operability of the fire prevention and fire safety measures. Your request for renewal of FSC is rejected under sub rule (3) of Rule 37 of DFS Rules-2010 due to following reason:

1. FCD found removed in kitchen.
2. Sprinkler at some places found hidden inside false ceiling and some cubical found constructed without sprinkler heads.
3. Exit signs were found removed.

In this regard as stipulated in sub Rule 37 of DFS Rules, 2010 you may apply with a fresh application for renewal of fire safety certificate under sub-rule (2) on Form "J" /MCD Portal with compliance of above shortcomings. The web links for DFS Act-2007/ Rules 2010 & Form "J" are as under:

[http://www.delhi.gov.in/wps/wcm/connect/doit\\_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/http://www.delhi.gov.in/wps/wcm/connect/doit\\_fire/FIRE/Home/Forms](http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms)

Yours faithfully

  
12/02/26  
(S. K. Dua)

Dy. Chief Fire Officer (WZ)  
Delhi Fire Service



Copy To:-

1. MCD Portal Id- 2026011300446 dated 13.01.2026.