

10



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



F6/DFS/MS/2025/EH/NDZ/ 261

Dated 12/06/2025

The Joint Commissioner of Police/ Lic,
1st Floor, Licensing Unit, Police Station
Defence Colony, New Delhi.

Sub: - Regarding issuance of fire safety certificate in r/o M/s Play (Restaurant), Shop No. TF 01, City Square Mall , Plot No-7,8, Shivaji Place, District Centre, Raja Garden, Delhi-110027.

Sir,

This has reference to your letter received through online I.D No. 2025052609133 dated 26/05/2025 on the subject cited above. In this connection this is to inform you that the above mentioned site was visited by the officer concerned of this department on 06/06/2025 in presence of Sh. Ashok Sharma (Fire Officer/ Mall) and verify the compliance of the shortcomings/ observations already communicated by this department vide letter of even no. F6/DFS/MS/GH/NDZ/232 dated 23/05/2025 and observed that the shortcomings have not been removed so far, (Copy enclosed).

Keeping in view of above, issuance of Fire Safety Certificate cannot be considered at this stage & rejected. You are requested to direct the applicant is rectify the above mentioned shortcomings under intimation to this department running/ occupancy of the eating house without Fire Safety Certificate is at the risk & responsibility of the management.

Yours faithfully,

(Atul Garg)
Director

Ph:-011-23414000

07/06/2025 10/6

Copy to:-

1. M/s Play (Restaurant), Shop No. TF 01, City Square Mall , Plot No-7,8, Shivaji Place, District Centre, Raja Garden, Delhi-110027

C-5

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001

No.F6/DFS/MS/GH/NDZ/ 232

Dated: 23/05/2025

To,

The Manager
M/S PLAY, Shop No. TF 01,
City Square Mall, Plot No. 7, 8,
Shivaji Place, District Centre,
Raja Garden, Delhi-110027.

Sub: Issuance of FSC (Fire Safety Certificate) in r/o M/S PLAY, Shop No. TF 01, City Square Mall, Plot No. 7, 8, Shivaji Place, District Centre, Raja Garden, Delhi-110027.

Sir,

This has reference to online 2025042306972 dated 23.04.2025, on the subject cited above. In this regard, it is to inform you that the site was inspected by the officer concerned of this department on 21/05/25 in the presence of Sh. Mahesh , Manager and following shortcomings were observed at the time of inspection.:-

1. Pumps, hose reels, hydrants, detection system, MCP, PA system, Sprinklers found nonfunctional.
2. Exit signage's found removed.

Hence, the case is rejected and Fire Safety Certificate (FSC) cannot be issued at this stage due to above shortcomings. Therefore, you are requested to rectify the above shortcomings and re-submit for further consideration in the matter.

Yours faithfully,


(Atul Garg)
DIRECTOR
Delhi Fire Service

Copy to:

1. The Joint commissioner of Police (Lic.) First floor, PS Defence Colony New Delhi.