



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F.6/DFS/MS/2025/SZ/137

Dated: 02/04/2025

To

The General Manager (Engg.),
NBCC Services Limited,
Plot No. 01, Sector-13,
Dwarka, New Delhi-110075

Sub: **Renewal of Fire Safety Certificate in r/o Educational Block at India International Institute of Democracy and Election Management located at Plot No. 01, Sector-13, Dwarka, New Delhi-110075.**

Sir,

This has a reference to your letter No. NSL/GM/IIIDEM/2025/29 dated 05/03/2025 received through outdoor diary No. 14108 dated 05/03/2025, on the subject above. In this connection, it is to inform you that the premise was inspected by the officers concerned from this department on 20/03/2025 in the presence of Sh. Bhaskar Singh (DPM) from fire safety point of view. During course of inspection, the shortcomings observed are as below: -

1. Electrical shaft found unsealed.
2. Smoke management system not integrated with MCP/Detection/Sprinklers.
3. Hose reel hose found provided but non-functional, nozzle missing.
4. Manually operated electrical fire alarm (MOEFA) found non-functional.
5. Public Address system found non-functional.
6. Hose-boxes near internal & external hydrant found removed/without nozzle & hoses.
7. Exit signage's found removed at some locations.
8. Wooden material in conference hall/meeting room not painted with fire retardant paint.
9. PVC material/sheet found used at 4th floor.

In view of the above, renewal of Fire Safety Certificate is rejected. You are advised to rectify the shortcomings under intimation to this department for further action in the matter. The occupancy of the premise/building in the absence of requisite fire safety arrangement shall be at the risk and responsibility of school management.

Yours faithfully,

(ATUL GARG)
DIRECTOR

Ph. 011-23414000

ATG

Copy to: -

1. The Secretary, IIIDEM, ECI, Sector-13, Dwarka, New Delhi-110075