



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

75
आज़ादी का
अमृत महोत्सव

No. F6/DFS/MS/BP/2026/ **303**

Dated: **22** /07/2026

To,

The Executive Engineer (Bldg.) HQ,
Municipal Corporation of Delhi,
8th Floor, Minto Road,
New Delhi.

Subject: Examination of building plans from fire safety point of view in r/o Plot No-WH-53, Block-WH, situated at Rewari Line Industrial area, Phase-I, Mayapuri, New Delhi-110064.


Sir,

With reference to online request ID No. 20030451 dated 03.07.2026 on the subject cited above. In this connection, it is to inform you that the matter has been examined and the following shortcomings have been observed:

1. The stilt floor is not open from the rear side as required in Clause 1.4.111 of UBBL-2016.

In view of the above-mentioned shortcomings and non-compliance with the provisions of UBBL-2016 and NBC-2016, Part-IV the building plans, as submitted, cannot be considered from the fire and life safety point of view and are hereby rejected.

Yours faithfully,


(A. K. Malik)

Chief Fire Officer (HQ)

Delhi Fire Service

