



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001**

7/5  
आज़ादी का  
अमृत महोत्सव

c/41

No. F6 /DFS/MS/Industrial/SZ/2025/ 128

Dated: 27/03/2025

To,

The Owner/Occupier/Manager,  
Plot No. E-1/B-1, Mohan Co-Operative Industrial Area/Estate,  
Mathura Road, New Delhi.

**Sub: - Regarding renewal of Fire Safety Certificate in r/o Building located at Plot No. E-1/B-1, Mohan Co-Operative Industrial Area/Estate, Mathura Road, New Delhi.**

Sir,

With reference to the letter bearing outdoor diary no. 14266 dated 10.03.2025 on the subject cited above, it is informed that the said building was inspected by officer concerned of this department on 19.03.2025 in the presence of Mr. Narender Singh (Caretaker/Supervisor) and following shortcomings were observed:

1. Fire Check Door (FCD's) found removed.
2. Automatic Fire Detection and Alarming System (ADAS) found non function.
3. Manual Operated Electrical Fire Alarm (MOEFA) system found non functional.
4. All water based systems like Hose reels Internal & Yard Hydrants, Sprinklers, Fire Pumps are non functional.
5. Diesel pump found removed.
6. Power cables running in the FHC must be removed and relocated in electrical shaft.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(Atul Garg)  
Director

Delhi Fire Service

Copy to:-

1. The Executive Engineer (Building), South DMC, Jal Vihar, Lajpat Nagar, New Delhi-24.