



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001



No F6/DFS/MS/2026/SZ/EH/17

Dated: 09/01/2026

FIRE SAFETY CERTIFICATE

Certified that the M/s Plus 91 (A unit of Figure Eight Foods Pvt. Ltd.) located at Shop No. HS 7, 2nd floor, Kailash Colony Main Market, Delhi-110048, in a building comprised of Basement + Ground + 03 upper floors and restaurant is running at 2nd floor only was inspected by the officer concerned of this department on 24.12.2025 in the presence of Mr. Sharif Khan (House Keeping (Manager) and found that the said premises have complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premise is fit for occupancy (Assembly Building) Group "D" for restaurant is running at 2nd floor only with effect from 09/01/2026 for a period of 03 (Three) years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 09/01/2026 at New Delhi by


(A.K. Malik)
Dy. Chief Fire Officer

ole

Copy to:

1. The Commissioner, MCD, Civic centre, New Delhi : to kindly ensure the occupancy as detailed above and deviation in construction if any : Online MCD Request ID-2025121215608 dated 13.12.2025.
2. The Manager, M/s Plus 91 (A unit of Figure Eight Foods Pvt. Ltd.) located at Shop No. HS 7, 2nd floor, Kailash Colony Main Market, Delhi-110048.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times & this FSC is valid for 2nd floor only.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management/occupier.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on
8. All the means of escape shall be kept free of any obstruction all the time to evacuate the occupant, in a safe manner, in the event of emergency.

http://www.delhi.gov.in/wps/wcm/connect/doiit_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/
http://www.delhi.gov.in/wps/wcm/connect/doiit_fire/FIRE/Home/Forms

INSPECTION REPORT

1. Name & address of the building	M/s Plus 91 (A unit of Figure Eight Foods Pvt. Ltd.) located at Shop No.HS 7, 2 nd floor, Kailash Colony Main Market, Delhi-110048.
2. Type of Occupancy	Assembly Building
3. Comprised of building	Basement + Ground + 03 upper floors
4. Type of Case	New Case (Restaurant is running at 2nd floor only)
5. Details of Previous NOC	-NA-
6. Fire Safety directives letter No	NBC Part-IV
7. Date of inspection	24.12.2025
8. Name of Inspecting Officer	Ajay Kumar Sharma ADO (Wazirpur/MN)
9. Name and designation of officers From the building side	Mr. Sharif Khan (House Keeping (Manager))
10. Year of Construction	2023 on MCD Portal
11. Applicant's letter No.	Online application No.2025121215608 dated 13.12.2025.

S. No	Minimum Standards on fire prevention and fire safety U/R 33	BBL/NBC Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	• Road width	6m	Provided	MR
	• Gate width	-NA-	-NA-	-NA-
	• Width of internal road	-NA-	-NA-	-NA-
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	02nos.	02nos.	MR
	• Basements	-NA-	-NA-	-NA-
	b. Width of staircases			
	• Upper Floor	1.5m	Provided	MR
	• Basements	-NA-	-NA-	-NA-
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	-NA-	-NA-	-NA-
	d. No. of continuous staircases to terrace	02nos.	Provided	MR
	e. Width of Corridor	-NA-	-NA-	-NA-
	f. Door Size	2 x 1.5m	Provided	MR
3.	Compartmentation			
	a) Fire check door	Required	Provided	MR
	b) Sealing of electrical shafts	-NA-	-NA-	-NA-
	c) Fire Rating of shaft door	-NA-	-NA-	-NA-
	d) Water Curtain	-NA-	-NA-	-NA-
	e) Fire Dampers	-NA-	-NA-	-NA-
4.	Smoke Management System			
	a) Basements	-NA-	-NA-	-NA-
	b) Upper floors	Mechanical/Natural	Natural	MR
5.	Fire Extinguishers			
	a) Total numbers	04nos.	Provided	MR
	b) Types	ABC/CO2	ABC/CO2	MR
	c) IS marking	ISI marked	Yes	MR
6.	First-Aid Hose Reels			
	a) Total numbers on each floor	02nos.	Provided	MR
	b) Length of hose reel hose	30mm	Provided	MR

AM

M/29-

	c) Nozzle diameter	5m	Provided	MR
7.	Automatic fire detection and alarming system			
	a) Type of detectors	-NA-	Provided	-NA-
	b) Location of Main Panel	-NA-	Provided	-NA-
	c) Location of Repeater Panel	-NA-	-NA-	-NA-
	d) Alternate source of power	-NA-	Provided	-NA-
	e) Hooters' Location	-NA-	Provided	-NA-
8.	MOEFA			
		Required	Provided	MR
9.	Public Address System			
		-NA-	-NA-	-NA-
10.	Automatic Sprinkler System			
	a) Basement	-NA-	-NA-	-NA-
	b) Ground & Upper Floors	-NA-	Provided	-NA-
	c) Sprinkler above false ceiling	-NA-	-NA-	-NA-
11.	Internal Hydrants			
	a) Size of riser/down-comer	100mm	Provided	MR
	b) Number of hydrants per floor	01nos.	Provided	MR
	c) Hose Box	01nos.	Provided	MR
12.	Yard Hydrants			
	a) Total number of hydrants	-NA-	-NA-	-NA-
	b) Hose Box	-NA-	-NA-	-NA-
13.	Pumping Arrangements			
	• Ground Level			
	➤ Discharge of main Pump	2280lpm	Provided	MR
	➤ Head of Main pump	40m	Provided	MR
	➤ Number of main pumps	01nos.	Provided	MR
	➤ Jockey Pump out put	180lpm	Provided	MR
	➤ Jockey pump head	40m	Provided	MR
	➤ Standby Pump out put	2280lpm	Provided at terrace	MR
	➤ Standby Pump Head	40m	Provided	MR
	➤ Auto Starting/Manual Stopping	Required	Provided	MR
	➤ Pump House Access	Required	Provided	MR
	Terrace level			
	➤ Discharge of pump	450lpm	900lpm	MR
	➤ Head of the pump	40m	40m	MR
	➤ Power Supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14.	Captive Water Storage for fire fighting			
	• Underground tank capacity			
	➤ Draw-off connection	-NA-	30k UG + 80k Terrace	-NA-
	➤ Fire service inlet	-NA-	-NA-	-NA-
	➤ Access to tank	Required	Provided	MR
	• Overhead Tank capacity			
		20,000ltr	Provided	MR
15.	Exit Signage.			
		Required	Provided	MR
16.	Provision of Lifts.			
	a) Pressurization of Lift Shaft	-NA-	-NA-	-NA-
	b) Pressurization of Lift lobby	-NA-	-NA-	-NA-
	c) Communication In lift Car	-NA-	-NA-	-NA-
	d) Fireman's Grounding Switch	Required	Provided	MR
	e) Lift Signage	Required	Provided	MR

- N/30 -

MR

	Standby power supply	-NA-	-NA-	-NA-
8.	Refuge Area.			
	a) Total Area	-NA-	-NA-	-NA-
	b) Location	-NA-	-NA-	-NA-
19.	Fire Control Room			
	a) Detector System Panel	-NA-	-NA-	-NA-
	b) Flow Switch Panel	-NA-	-NA-	-NA-
	c) PA System Panel	-NA-	-NA-	-NA-
	d) Battery backup	-NA-	-NA-	-NA-
	e) Building Floor Plans	-NA-	-NA-	-NA-
20.	Special Fire Protection System for Protection of special Risks, if any:	-NA-	-NA-	-NA-

Accordingly, the fire protection systems provided in the building were tested/ checked randomly and found in working condition at the time of inspection. It is further clarified that noting N/9 related exclusively to the first floor, as duly clarified through the corrigendum dated 21.06.2024.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required as stipulated in NBC Part-4, and removal of shortcomings issued vide letter no. 289 dated 23.06.2025, under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rule 2010.

[Signature]
 27/12/25
 Signature of the Inspecting Officer
 Name Ajay Kumar Sharma
 Designation ADO(Wazirpur/MN)

DO (SD) *[Signature]*
 31/12/25

[Signature]
 27/12/25

[Signature]
 31/1/26
 A.K. MALIK
 Principal Engineer

By. CFO to Govt.
[Signature]
 03/01/26

By. CFO (STR)
[Signature]

[Signature]
 31/1/26
 A.K. MALIK

[Signature]