



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F.6/DFS/MS/School/2025/SZ/ 50

Dated: 22/01/2025

To

The Principal,  
PM Shri Kendriya Vidyalaya,  
Sector-12, Dwarka,  
New Delhi-110078

**Sub: Renewal of Fire Safety Certificate in r/o PM Shri Kendriya Vidyalaya, Sector-12, Dwarka, New Delhi-110078**

Sir,

Please refer to your email dated 02/01/2025, on the subject above. In this connection, it is to inform you that the premise was visited by the officer concerned of this department on 13/01/2025 with a view to verify the availability and operability of fire safety arrangements in your presence. During course of inspection, the shortcomings observed are as below.

1. Hose reel hose provided found non-functional.
2. Terrace fire pump was not on auto mode.
3. Exit signage found removed at some places.

In view of the above, the application for renewal of fire safety certificate is rejected. You are requested to rectify the shortcomings above under intimation to this department for further action. The occupancy of the premise/building in the absence of requisite fire safety arrangement shall be at the risk and responsibility of school management.

Yours faithfully,

(ATUL GARG)  
DIRECTOR

T. No. 011-23414000

01/25

Copy to: -

1. The Assistant Commissioner, KVS Delhi Region, JNU Campus, New Mehrauli Road, New Delhi-110067