

C-60

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

75
आजादी का
अमृत महोत्सव

No. F6/DFS/MS/School/WZ/2025/ 646

Dated: 18/08/2025

To,

The Principal,
P.P. International School,
LD Block, Pitampura, New Delhi-110034.

Sub: Regarding renewal of FSC/NOC in r/o. P.P. International School, located at LD Block, Pitampura, New Delhi-110034.

Sir,

With reference to your letter No. outdoor dairy No. 3525 dated 08/07/2025, on the subject cited above. In this connection, it is to inform you that the said premises was inspected by the officer concerned of this department on 30/07/2025, in the presence of M/s. Deepi Bector to see the functioning of the fire safety arrangements/equipments provided in the building.

During inspection, it has been observed that the said school is running at ground & 1st floors, in a building is comprised of basement + ground + 04 upper floors, was issued FSC vide letter No F6/DFS/MS/School/WZ/2022/1225 dated 10/11/2022 for ground and 1st floor only. fire safety arrangements such as, Fire Extinguishers, First Aid Hose Reels, Terrace pump etc, are provided. However, following shortcomings were observed: -

1. First Aid Hose Reels are provided but not functional.
2. Internal Hydrants are provided but not functional
3. Terrace fire pump of 900 LPM & 220 LPM are provided but not functional.
4. Exit signage's are found removed at some places.

In view of above shortcomings, the application for renewal Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier.

Yours faithfully,


14/08/2025
Virendra Singh
Chief Fire Officer


13/08/2025

Copy To:-

1. The Director, Directorate of Education Old Secretariat Delhi - 110054.