



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001



No. F6/DFS/MS/2025/School/ 159

Dated: 14/02/2025

FIRE SAFETY CERTIFICATE

Certified that the Public Model School located at K-Block, Jahangirpuri, Delhi-110033 comprised of Ground & 02 upper floors owned/ occupied by Public Model School was issued Fire Safety Certificated vide this office letter no. F6/DFS/MS/School/2021/680 dated 31.08.2021. The premise was inspected by the officer concerned of this department on 31.01.2025 in the presence of Mr. Kushal Kumar (Manager) and observed that all the fire prevention and fire safety arrangements as provided in the premise found in good working condition. The premise have therefore deemed complied with the requirements under rule 33 of the Delhi Fire Service Rules, 2010 and the building premise is fit for occupancy under "Group B Educational (School)" with effect from14/02/2025 for a period of three years, in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under rule 40, subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010,

Issued on14/02/2025 at New Delhi

(Atul Garg)
 Director

Ph:- 011-23414000

Copy to:-

1. The Dy. Director of Education, GNCT of Delhi, Zone-IX, District North West-A, Shalimar Bagh, BL- Block, Delhi- 110088.
2. The Manager, Public Model School located at K-Block, Jahangirpuri, Delhi-110033.

Conditions for the validity of Fire Safety Certificate:

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection.
3. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
4. All the staff members must know the correct method of operation of firefighting system.
5. The owner / occupier shall submit a declaration every year in Form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on <http://delhi.gov.in/wps/wcm/connect/doi/fire/FIRE/Home/Forms>.
6. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
7. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".

INSPECTION REPORT

1. Name & address of the building : Public Model School, K-Block, Jahangirpuri, Delhi-110033.
2. Type of Occupancy : Educational
3. Type of Case : Renewal
4. Composition of building : Ground & 02 upper floors
5. Details of previous NOC : F6/DFS/MS/School/2021/680 dated 31.08.2021
6. Fire Safety directives letter No : Nil
7. Date of inspection : 31.01.2025
8. Name of the Inspecting Officers : ADO (RN)
9. Name and designation of officers
from the building side : Mr. Kushal Kumar (Manager)
10. Year of Construction : 1987
11. Applicant's letter No. : Online E-Mail I.D dated 17.01.2025


	Minimum Standards on fire prevention and fire safety U/R 33	Requirements as per Rules 35 (6)	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	06m	06m	MR
	• Gate width	Directly Accessible	Directly Accessible	MR
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	02	02	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	1.50m	1.50m & 77cm	MR (old building)
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
d. No. of continuous staircases to terrace	NA	NA	NA	
e. Width of Corridor	NA	NA	NA	
f. Door Size	01m	1.05m	MR	
3	Compartmentation.			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke Management System.			
	• Basements	NA	NA	NA
	• Upper floors	Required	Natural Ventilation	MR
5	Fire Extinguishers			
	• Total numbers	08nos	10nos	MR
	• Types	ABC/Co2	ABC-10	MR

	• ISI marking	Yes	Yes	MR
6	First-Aid Hose Reels.			
	• Total numbers on each floor	01	01 each floor	MR
	• Length of hose reel hose	30m	30m	MR
	• Nozzle diameter	5mm	5mm	MR
7	Automatic fire detection and alarming system			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8	MOEFA	Required	Provided	MR
9	Public Address System.	NA	NA	NA
10	Automatic Sprinkler System.			
	• Basement	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11	Internal Hydrants			
	• Size of riser/down-comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA
	• Hose Box	NA	NA	NA
12	Yard Hydrants.			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13	Pumping Arrangements.			
	• Ground Level			
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey Pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby Pump out put	N/A	N/A	N/A
	➤ Standby Pump Head	N/A	N/A	N/A
	➤ Auto Starting/ Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace level			
	➤ Discharge of pump	450 LPM	450 LPM	MR
	➤ Head of the pump	40m	40m	MR
➤ Power Supply	NA	NA	NA	
➤ Auto Starting of pump	Required	Provided	MR	
14	Captive Water Storage for fire fighting.			
	• Underground tank capacity	NA	NA	NA
	➤ Draw-off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA


	• Overhead Tank capacity	10,000 LTR	10,000 LTR	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	N/A	N/A	N/A


The fire protection systems provided in the building were tested/ checked randomly and found in working condition at the time of inspection.

Keeping in view the satisfactory compliance of the minimum standards on fire prevention and fire safety required as stipulated in NBC Part 4, the FSC issued vide letter of even no. F6/DFS/MS/School/2021/680 dated 31.08.2021 renewal under rule 37 of the Delhi Fire Service Rules, 2010 is recommended.


 Signature of the Inspecting Officer
 Name :- C.L. Meena
 Designation:- ADO/RN

D.B. Mukharjee (DO/NW)


 Dy cfo (w2) - MK


 6/21/2025


 Director



DCFO/..... 381/1162
 Dated:..... 6/21/2025