

c 27

FORM 'H': FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[See sub-rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No.F.6/DFS/MS/School/2025/NDZ/ 301

Dated: 27/03/2025

FIRE SAFETY CERTIFICATE

Certified that the R.K. Modern Public School located at C-146, Street No.1, Pratap Nagar, Saboli Extn., Shahdara, Delhi-110093, school building comprised of Ground plus two upper floors but school is running on ground & 1st floor only (2nd Floor is sealed) owned / occupied by R.K. Modern Public School, has already been issued Fire Safety Certificate Vide Letter No. F6/DFS/MS/School/2015/NDZ/2155 dated 10/12/2015. The premises was re-inspected by the officer concerned of this department on 18/03/2025 in the presence of Sh. S.P. Bhargav, Manager and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with Circular No. 3298-3398 dated 01/03/2011 issued by Director of Education and found that the school building is fit for occupancy class "Educational" (Group-B) for Ground & 1st floor only, with effect from 27/03/2025 for a period of three years in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rules, 2010. Subject to conditions printed below.

Issued on 27/03/2025 at New Delhi by


(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

Copy to :-

1. The Principal, R.K. Modern Public School, C-146, Street No.1, Pratap Nagar, Saboli Extn., Shahdara, Delhi-110093.
2. The Dy. Director of Education, B-Block, Yamuna Vihar, North-East, Delhi-110053.

Conditions for the validity of Fire Safety Certificate:

1. Fire Safety Certificate is valid for Ground & 1st Floor only.
2. All the means of escape / entry / exit shall be kept free from any obstruction.
3. All the fire safety arrangement provided there in shall be maintained in good working conditions at all times.
4. Any loss of life or property due to non- functional fire safety measure shall be at the responsibility of the management.
5. All the staff members must know the correct method of operation of fire fighting system.
6. This Fire Safety Certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3. of UBBL-2016), if any.
7. "The owner / Occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
8. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in.

INSPECTION REPORT

- H/S
1. Name & address of the building: R.K. Modern Public School, C-146, Street No.1, Pratap Nagar, Saboli Extn., Shahdara, Delhi-110093.
 2. Type of Occupancy : Educational, Group-B(School)
 3. Building Comprised of : Ground plus two upper floor only but school is running on Ground & 1st floor only. 2nd Floor is sealed.
 4. Type of Case : Renewal
 5. Details of previous NOC No. F6/DFS/MS/School/2015/NDZ/2155 dated 10/12/2015
 6. Fire Safety directives Letter No. : DOE Cir. 3298-3398 Dated 01/03/2011
 7. Date of inspection : 18/03/2025
 8. Name of the Inspecting Officer : A.K. Jaiswal (D.O.)
 9. Name and designation of Officer from the building side : Mr. S.P. Bhargav, Manager
 10. Year of Construction : 2001
 11. Applicant's letter no received : 260/2025 dated 06/02/2025

S No	Minimum standards on fire prevention and fire safety U/R 33	DOE Cir. 2011 requirement	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	6m	6m	MR
	• Gate width	NA	NA	NA
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	1	2	MR
	• Basements	NA	NA	NA
	Width of staircases			
	• Upper floors	1.50m	1.38m & 0.88m	MR
	• Basements	NA	NA	NA
	Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	b. No of continuous staircase to terrace	1	1	MR
	c. Width Of Corridor	1.50m	1.50m	MR
	d. Door Size	1.00m	1.00m	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	NA	NA	NA
	• Upper floors	NA	NA	NA
5.	Fire Extinguishers			
	• Total numbers	4 Nos	6 Nos	MR
	• Types	ABC /Co ₂	Provided	MR
	• ISI marking	ISI Marked	Provided	MR

A

M/G				
6.	First – Aid Hose Reels			
	• Total numbers on each floor	NA	NA	NA
	• Length of hose reel hose	NA	NA	NA
	• Nozzle diameter	NA	NA	NA
7.	Automatic fire detection and alarming system			
	• Type of detector	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8.	MOEFA			
9.	Public Address System			
10.	Automatic Sprinkler System			
	• Basements	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants			
	• Size of riser/down- comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA
	• Hose Bo.ç	NA	NA	NA
12.	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13.	Pumping Arrangements			
	• Ground Level			
	• Discharge of main pump	NA	NA	NA
	➤ Head of main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Staring/Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	NA	NA	NA
	➤ Head of the pump	NA	NA	NA
	➤ Power supply	NA	NA	NA
	➤ Auto starting of pump	NA	NA	NA
14.	Captive water Storage for fire fighting			
	• Underground tank capacity	NA	NA	NA
	➤ Draw of connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	NA	NA	NA

2/2

15	Exit Signage	NA	NA	NA
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17.	Standby power supply	NA	NA	NA
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

Note:-Building presently comprised of Ground plus two upper floors. School is running only on Ground & 1st floor. 2nd floor is sealed & not in use. Undertaking regarding this is placed at C-24.

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter No. F6/DFS/MS/School/2015/NDZ/2155 dated 10/12/2015 renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

Ashok Kumar Jaiswal
20/03/2015

Signature of the Inspecting Officer
Name : Ashok Kumar Jaiswal
Designation : D.O. (East)

Dy. C.F.O. / NDZ

NDZ
21/03/2015

C.F.O.

22/3/2015

Director
22/03/2015

Director
25/3/2015
sir,
F.T. is added for 2nd fl.