

c/60

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001

No. F.6/DFS/MS/NDZ/2025/ 22

Dated: 13 .01.2025

To,

Sh. Vipin Sharma,
Dy. Chief Engineer/Const. - I,
State Entry Road, New Delhi.

Subject:- Regarding issuance of fire clearance certificate for Railway Offices & Rest House for Railway operational use at Tilak Bridge, New Delhi.

Sir,

Please refer to your to Letter no. 120-W/C/Misc./ORH/TKJ/PT-V dated 16/12/24.on the subject cited above. In this connection, this is to inform you that the site was visited by officers concerned of the department on dated 02/01/25 in presence of Sh. Shiv Kumar Puri, AEE Sh. Vipin Dy. Chief Engineer and found following shortcomings as under:

1. Fire check door are provided partially required to be provided at each staircase.
2. Pressurization of staircase and lifts shaft and lobby not provided.
3. Sprinkler is not provided at service floor.
4. Electrical shaft are not properly sealed.
5. Flow switches Panel is not provided at FCR.
6. Lift & Exit signages are not provided.

In view of above, Fire Safety Certificate cannot be issued. Therefore, you are requested to rectify the shortcomings for further consideration in the matter.

Yours faithfully,

(Atul Garg)
DIRECTOR
Delhi Fire Service

Copy to:-

1. The Chief Engineer /C/NC/K. Gate, State Entry Road, Delhi: to kindly ensure the use of occupancy as detailed above.
2. CEE/C/TKJ, Northern Railway, State Entry Road, New Delhi.
3. M/s Aadhar Stumbh Township Pvt. Ltd., 2nd floor, plot no. 2, Anand Plaza, LSC Sainik Vihar, Pitampura, New Delhi-34.