



259

FORM 'H': FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[See sub-rule (1) of rule 35]

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001

No F 6/DFS/MS/GH/2026/NDZ/18

Dated: 09/01/2026

FIRE SAFETY CERTIFICATE

Certified that the M/s Raj Mahal Inn located at 450-452, Gali Chandi Wali, Mantola, Pahar Ganj, New Delhi comprised of Ground + 3 upper floors, Ground floor (05 Guest rooms + Reception), 1st to 3rd floor (07 Guest rooms at each floor) issued FSC by this department vide letter No F6/DFS/MS/GH/NDZ/2023/51 dated 23.02.2023 for 26 Guest rooms up to third floor only. The premise was re-inspected by the officer concerned of this department on 31.12.2025 in the presence of Mr. Anil Manocha and observed that all the fire prevention and fire safety arrangements as provided in the premises found in good working condition. The premises have therefore deemed complied with fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the building/ premise is fit for occupancy "Class Residential (Sub Division-A-1) Ground floor (05 Guest rooms + Reception), 1st to 3rd floor (07 Guest rooms at each floor), total 26 guest rooms up to third floor only, with effect from 09/01/2026 for a period of three years in accordance with the Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40, subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 09/01/2026 at New Delhi, by


9/1/26
(Dr. S.K. Tomar)

Dy. Chief Fire Officer

Copy to: -

1. The Commissioner, MCD, Civic Centre, New Delhi- to ensure the occupancy as detailed above- (Ref. MCD Portal, ID No. 2025122015928).
2. M/s. Raj Mahal Inn located at 450-452, Gali Chandi Wali, Mantola, Pahar Ganj, New Delhi.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate through MCD portal (<https://www.mcdonline.gov.in>) along with a copy of this Certificate, six months prior to its expiry.
7. The means of escape shall be kept unobstructed/ unlocked for unhindered evacuation in case of an emergency.
8. Any flammable material for interior decoration is prohibited.

INSPECTION REPORT

1. Name & address of the building : M/s Raj Mahal Inn located at 450-452, Gali Chandi Wali Mantola, Pahar Ganj, New Delhi.
2. Type of Occupancy : Residential, Sub Division-A-1
3. Building Comprised of : Ground + 03 Upper Floors
Ground floor (Reception + 05 Guest rooms), 1st to 3rd floor (7 Guest rooms at each floor), **Total 26 Guest Rooms.**
4. Type of Case : Renewal
5. Details of Previous NOC : F6/DFS/MS/GH/NDZ/2023/51 Dated- 23/02/2023
6. Fire Safety directives letter No : Nil
7. Date of inspection : 31/12/2025
8. Name of Inspecting Officer : R.K.Sinha, ADO (Jawala Puri)
9. Name and designation of officers from the building side : Mr. Anil Manocha
10. Year of Construction : 2013 As per MCD Portal
11. Applicant's letter No. : MCD Application ID No. 2025122015928 dated 20/12/2025

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	As per inspection report dated - 15/02/2023	Provided at site	Remarks MR/NMR
1.	Access to building			
	Road width	Required	06 m	MR
	Gate width	NA	NA	NA
	Width of internal road	NA	NA	NA
2.	Number, Width, Type & Arrangement of Exits			
	Number of staircases			
	Upper Floors	01 nos.	01 nos.	MR
	Basements	NA	NA	NA
	Width of staircases			
	Upper Floor	150 cm	150 cm	MR
	Basements	NA	NA	NA
	Protection of exits			
	Fire check door	NA	NA	NA
	Pressurization	NA	NA	NA
	No. of continuous staircases to terrace	NA	NA	NA
	Width of Corridor	NA	NA	NA
	Door Size	01 m	01 m	MR
3.	Compartmentation			
	Fire check door	NA	NA	NA
	Sealing of electrical shafts	NA	NA	NA
	Fire Rating of shaft door	NA	NA	NA
	Water Curtain	NA	NA	NA
	Fire Dampers	NA	NA	NA
4.	Smoke Management System			
	Basements	NA	NA	NA
	Upper floors	Required	Natural/Exhaust fan	MR
5.	Fire Extinguishers			
	Total numbers	08 Nos.	10 Nos.	MR
	Types	ABC & Co2	ABC & Co2	MR

N-17

M/s Raj Mahal Inn at 450-452, Gali Chandi Wali, Mantola, Pahar Ganj, New Delhi.

	IS marking	Required	Provided	
6.	First-Aid Hose Reels			
	Total numbers on each floor	01	01	MR
	Length of hose reel hose	30 m	30 m	MR
	Nozzle diameter	05 mm	05 mm	MR
7.	Automatic fire detection and alarming system			
	Type of detectors Co type	Required	Provided	MR
	Location of Main Panel	Gr. floor	Provided	MR
	Location of Repeater Panel	NA	NA	NA
	Alternate source of power	Required	Provided	MR
	Hooters' Location	At each floor	Provided	MR
8.	MOEFA	NA	Provided	NA
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	Basement	NA	NA	NA
	Upper Floor	NA	NA	NA
	Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants			
	Size of riser/down-comer	NA	NA	NA
	Number of hydrants per floor	NA	NA	NA
	Hose Box	NA	NA	NA
12.	Yard Hydrants			
	Total number of hydrants	NA	NA	NA
	Hose Box	NA	NA	NA
13.	Pumping Arrangements			
	Ground Level			
	Discharge of main Pump	NA	NA	NA
	Head of Main pump	NA	NA	NA
	Number of main pumps	NA	NA	NA
	Jockey Pump out put	NA	NA	NA
	Jockey pump head	NA	NA	NA
	Standby Pump out put	NA	NA	NA
	Standby Pump Head	NA	NA	NA
	Auto Starting/Manual Stopping	NA	NA	NA
	Pump House Access	NA	NA	NA
	Terrace level			
	Discharge of pump	450 lpm	450 lpm	MR
	Head of the pump	30 m	30 m	MR
	Power Supply	Required	Provided	MR
	Auto Starting of pump	Required	Provided	MR
14.	Captive Water Storage for fire fighting			
	Underground tank capacity	NA	NA	NA
	Draw-off connection	NA	NA	NA
	Fire service inlet	NA	NA	NA
	Access to tank	NA	NA	NA
	Overhead Tank capacity	5,000 ltrs	5,000 ltrs	M

N-18

M/s Raj Mahal Inn at 450-452, Gali Chandi Wali, Mantola, Pahar Ganj, New Delhi.

15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	Pressurization of Lift Shaft	NA	NA	NA
	Pressurization of Lift lobby	NA	NA	NA
	Communication In lift Car	NA	NA	NA
	Fireman's Grounding Switch	NA	NA	NA
	Lift Signage	NA	NA	NA
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area.			
	Total Area	NA	NA	NA
	Location	NA	NA	NA
19.	Fire Control Room			
	Detector System Panel	NA	NA	NA
	Flow Switch Panel	NA	NA	NA
	PA System Panel	NA	NA	NA
	Battery backup	NA	NA	NA
	Building Floor Plans	NA	NA	NA
20.	Special Fire Protection System for Protection of special Risks, if any:	NA	NA	NA

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Keeping in view of deemed compliance of the minimum standards of fire prevention and fire safety measures as required under rules it is **recommended to renew** the fire safety certificate issued vide letter no. F6/DFS/MS/GH/NDZ/2023/51 dated 23/02/2023 under Rule 37 of the Delhi Fire Service Rules, 2010.

DEEMED APPROVED AFTER 18/01/2026

ADJ
ADJ/SWP
11/1/2026

Signature of Inspecting Officer
Name : Rajeev Kumar Sinha
Designation : ADO/Jawala Puri.

ADJ
ADJ/SWP
05/01/26

Dy. CFO (NDZ)

ADJ/SWP
05/11/26

Principal Director

My. CFO to ADJ/SWP

ADJ/SWP
06/01/26

My. CFO (NDZ)

ADJ/SWP

ADJ/SWP
05/11/26

ADJ